

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

c-7

NO. FG/DFS/MS/8ehod/2013/317

Dated: 15/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the MCD Primary Boys School, Tajpur Kalan Delhi 110036 is comprised of Block-I (4 No's Sheds), Block-II (Five Rooms + One Hall on G.F) owned/occupied by MCD Primary Boys School complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 28/03/2013 in the presence of Ms. Alka Gupta and that the building / premises is fit for occupancy of Educational building with effect from 15/05/2013 for a period of three years, subject to following conditions.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 15/05/2013 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Principal, MCD Primary Boys School, Tajpur Kalan Delhi 110036
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.



N-1

INSPECTION REPORT

1. Name & address of the building: MD Primary Boys School, Tajpur Kalan, Delhi
2. Type of Occupancy: Educational
3. Type of Case: New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: \_\_\_\_\_
5. Fire Safety directives letter No: Circular, Director of Edum. 1/3/11
6. Date of inspection: 28-3-2013
7. Name of the Inspecting Officers: ADO SHYAM LAL
8. Name and designation of officers from the building side: MS. AIKA Gupta (Teacher)
9. Year of Construction: 1948, 1990, 2004, (Ground only with hall - approx 50m<sup>2</sup> with two exit - 1.5m each)
10. Applicant's letter No. : NIL dated -

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	Accessible	9 m MIR
	• Gate width	-/-	3.75 m MSR
	• Width of internal road	-/-	open ground MIR
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	N/A	
	• Upper Floors		
	• Basements		
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits		
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace		
	g. Width of Corridor		
	h. Door Size	1 m	1.04 m MIR
3	Compartmentation.		one door less than 1.5m
	• Fire check door		
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	
	• Upper floors	12 a/c per hour	

*Graded Dir. 1/3/2011*

N/A

*one door less than 1.5m*

N/R

N/R





Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		NIR	
15	Exit Signage.		NIR	
16	Provision of Lifts.		NIA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>		NIA	
17	Standby power supply		NIR	
18	Refuge Area.		NIA	
	➤ Total Area		NIA	
	➤ Location		/	
19	Fire Control Room		NIR	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	NIL	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

D/o.  
(N/w)  
Sush  
2/4/13

Signature of the Inspecting Officer

Name

Designation

(SHYAM LAL)  
Assitt. Divn. Officer.