

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/315

Dated: 15/05/2013

FIRE SAFETY CERTIFICATE

Certified that the Maharaja Agarsen Public School is comprised of 9 Class Room on Ground floor Only located at 120/15, Shiv Mandir, Bakhtawarpur Delhi-110036 has already been issued fire safety certificate Vide letter no F-6/DFS/MS/2010/05 Dated 01/01/2010 have complied with the fire prevention and fire safety requirements in accordance with Circular dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 29/04/2013 in the presence of Sh. Shashi Nath Mishra and that the building the premises is fit for occupancy of Group Class B (Educational) with effect from 15 / 05 /2013 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 15/05/2013 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Maharaja Agarsen Public School, 120/15, Shiv Mandir, Bakhtawarpur Delhi-110036.
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.

INSPECTION REPORT

1. Name & address of the building: Maharaja Agrasen Public School, Baktawar Pur, Delhi-
2. Type of Occupancy: Educational.
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. F-6/DPS/MS/200/05 Dated: 01/10/2010
5. Fire Safety directives letter No: Circular, Dir. of Edun. 17-1-2005.
6. Date of inspection: 29/4/2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Sh. Shashi Nath Mishra.
9. Year of Construction: 2005, (Ground only.)
10. Applicant's letter No.: Nil dated 10-4-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks
		<u>Circular, Dir. of Edun. 17/1/2005</u>	MR/NMR
1	Access to building		
	• Road width	<u>Accessible 6 m</u>	<u>MIR</u>
	• Gate width	<u>— 2.91 m</u>	<u>MIR</u>
	• Width of internal road	<u>N/A N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	<u>N/A</u>	
	• Upper Floors		
	• Basements		
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits		
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace		
	g. Width of Corridor		
	h. Door <u>width-</u>	<u>1 m 1.22 m one door</u>	<u>MIR</u>
3	Compartmentation.		
	• Fire check door	<u>N/A</u>	
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	<u>30 a/c per hour</u>	<u>N/A</u>
	• Upper floors	<u>12 a/c per hour</u>	<u>1</u>

N-3


5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	<p>4 ABC (CO2 (2.5kg)) ISI marked</p>	<p>provided provided provided</p>	<p>MIR -1- -1-</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m 5 mm</p>	<p>NIR /</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		<p>NIR /</p>	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		<p>NIR /</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		<p>NIR /</p>	
12	Yard Hydrants..			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		<p>NIR /</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		<p>NIR /</p>	

4-4

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NIR
15	Exit Signage.			NIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			N/A
17	Standby power supply			NIR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			NIR
20	Special Fire Protection Systems for Protection of special Risks, if any:	—		NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

Designation

Signature
21/5/13
DO. (New)

Signature of the Inspecting Officer

Name

Designation

Signature
30/4/2013
(SHYAM LAL)
Asstt. Divn. officer