

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/2013/298

Dated: 15/05/2013

FIRE SAFETY CERTIFICATE

Certified that the **St. Marks Senior Secondary Public School** located at **A-Block, Meera Bagh, New Delhi** comprised of Ground + three upper floors. **St. Marks Senior Secondary Public School** was issued NOC vide this office letter no. F.6/DFS/MS/2010/807 Dated 17/3/2010. The premises was re-inspected by the officer concerned of this department on **09/03/2013** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 01/03/2011 and the building/ premises is fit for occupancy Class **Educational** with effect from **15/05/2013** for a period of **three years** subject to conditions printed below.

Issued on 15/05/13 at New Delhi.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel No. - 23414250

9c  Email-cfowz.dlfire@nic.in

Copy to:

1. The Manager, St. Marks Senior Secondary Public School, A- Block, Meera Bagh New Delhi.
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt., Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

(Ground + Three upper floors)

INSPECTION REPORT

1. Name & address of the building : St. Marks Senior Sec. School, A-Block, Meera Bagh
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/2010/807 Dated: 17/3/2010
5. Fire Safety directives letter No : F.6/DFS/MS/BS/97 ✓
6. Date of inspection : 09/3/2013 ✓
7. Name of the Inspecting Officers : ADO S.k. Dua ✓
8. Name and designation of officers from the building side : Sh. S. D. Bhoselwaj ✓
9. Year of Construction : 1998
10. Applicant's letter No. : Nil dated 18/02/2013 ✓

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	4.5 mtr.	Provided	MR
	• Width of internal road	NR	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	Provided (04)	MR
	• Basements	NA	NA	NA
	b. Width of staircases	—	—	—
	• Upper Floors	1.5 mtr.	1) 2.15m 2) 1.5m	MR
	• Basements	NA	3) 1.5m 4) 1.5m	NA
	c. Protection of exits	—	—	—
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	02	Provided	MR
	g. Width of Corridor	1.5 mtr	Provided	MR
	h. Door Size	Old case	0.98 mtr.	Old case MR

20-571
284
10-6811

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA Exhaust Fan Provided	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	22 ISI marked	Provided ✓ Provided ✓ Provided ✓	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 30 m 5 mm	Provided ✓ Provided ✓ Provided ✓	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	Required	Provided ✓	MR
9	Public Address System.	NR	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor (in Auditorium open stage) • Sprinkler above false ceiling 	NA Required NA	NA Provided ✓ NA	NA MR NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided ✓	MR

- N/A -

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	02 Required	Provided ✓ Provided ✓	MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		N/A	
		900 LPM & 220 LPM	Provided ✓	MR
		40 mtr. each	Provided ✓	MR
		Required	Provided ✓	MR
		Required	Provided ✓	MR
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	Required	50,000 Lts. ✓	MR
		NR	NA	NA
		NR	Provided ✓	MR
		Required	Provided ✓	MR
		20,000 Lts.	Provided ✓	MR
15	Exit Signage.	Required	Provided ✓	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 		N/A	

- M/11 -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	Required	Provided 100 kW	MR
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	ND	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....


 Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Signature of the Inspecting Officer

Name

Designation