

**FIRE SAFETY CERTIFICATE**

Certified that the **Symphony Celebration Pvt. Ltd.** located at **D-11, Udyog Nagar, Rohtak Road, Delhi** comprised of **Basement, Ground + two upper floors** owned and occupied by **Symphony Celebration Pvt. Ltd** with store in Basement, Banquet Halls on Ground & first floor & Restaurant on second floor have been re-inspected by the officers concerned of this department on **22/02/2013** in the presence of **Mr. Pankaj Gupta (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, is fit for occupancy class **Assembly** with effect from **14/05/2013** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions printed below.

Issued on 14/05/13 at New Delhi.



(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Tel. No. - 011-23414250  
Email- cfowz.dlfire@nic.in

Copy to:

The Authorized Signatory, Symphony Celebration Pvt. Ltd., D-11, Udyog Nagar, Rohtak Road, Delhi.

**Following fire safety directives must be adhered to**

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

- 14/11/12

May kindly see the letter received from Sh. Pankaj Gupta (GM), M/s Symphony celebrations private limited, D- 11, Udyog Nagar, Rohtak road, on the subject cited above. In this connection it is to inform you that above said premise was issued NOC from Delhi Fire Service vide letter no. F.6/DFS/MS/BP/2000/1728 dated 25/09/2000 and later on letter no. F.5(J)/DFS/2003/623 dated 09/10/2003 was issued. The NOC was issued for Basement and Ground floor being used for industrial purposes. Then party applied for NOC for Banquet hall on ground and first floor and shortcoming letter no. ~~F.5(J)/DFS/2003/623~~ dated ~~09/10/2003~~ was issued in which, party was asked to provide F.6/DFS/MS/2008/363 dated 13/2/08

- The entire building should be provided with Automatic sprinkler system and
- One alternate staircase in basement is required.

Now the party has applied NOC for running banquet halls on ground and first floor & a restaurant on second floor. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : Symphony Celebrations Pvt. Ltd., D-11, Udyog Nagar
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F-5/(J)/DFS/2003/623 Dated: 09/10/2003
5. Fire Safety directives letter No. : [ F6/DFS/MS/2000/1728 Dated: 25/09/2000  
F.6/DFS/MS/2008/363 dated 13/2/2008 ]
6. Date of inspection : 22/02/2013
7. Name of the Inspecting Officers : DO (MN) & ADO (WP)
8. Name and designation of officers  
From the building side : Sh. Pankaj Gupta (Manager)
9. Year of Construction : 2002
10. Applicant's letter No. : Letter No. NIL Dated: 20/12/2012

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6 mts	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NR	NA	NA

- 1915-

2. <b>Number, Width, Type &amp; Arrangement of Exits</b>				
a. Number of staircases <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basement</li> </ul> b. Width of staircases <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basement</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul> d. No. of continuous staircases to terrace	3	Provided	M.R.	
	4	Provided	M.R.	
	Old case	1.82m, 1.81m & 1.50m	MR old case	
	1.5 mtrs	1.82 m, 1.81 m, 1.72 m, 1.25m, 1.26m & 0.72m	MR old case	
	Required	Provided	MR	
	NR	NA	NA	
	One	Provided	MR	
	1.5 mtr	Provided	MR	
	e. Width of Corridor f. Door size Banquet Hall (old) Restaurant (new)	Old case (GF)	2.7m, 2.4m & 1.26m	MR $\frac{1}{2}$
		(FF) 2 X 2.0 mts	2.7m, 2.4m & 1.26m  1 X 2.8 mtrs. 1 X 2.0 mts	MR $\frac{1}{2}$
	3. <b>Compartmentation.</b>			
<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR	
	Required	Provided	MR	
	NR	NA	NA	
	NR	NA	NA	
	NR	NA	NA	
4. <b>Smoke Management System.</b>				
<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR	

- M/16

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	28	Provided	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC-5 kgs, CO <sub>2</sub> -4.5 Kg, WCO <sub>2</sub> - 9.0 lts	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	On Ground Floor	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NR	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	On each floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	M.R

- N/19 -

	➤ Detector System Panel	NR	NA	NA
	➤ Flow Switch Panel	NR	NA	NA
	➤ PA system Panel	NR	NA	NA
	➤ Batter backup	NR	NA	NA
	➤ Building Floor plans	NR	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	No	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



Signature of the Inspection Officer

Name S. K. Dua

Designation ADO (WP)