

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 011-23412593 E-mail : cfohg.dlfire@nic.in Ph. 23414333

No.F6/DFS/MS/EH/2013/ 308

Dated : 15/5/2013

**FIRE SAFETY CERTIFICATE**

Certified that the **The Big Chill Cafe Pvt. Ltd.** located at **Shop No. 122,272-274,DLF Place Saket,New Delhi.** comprised of **3 Basement, Ground + 2 Upper Floors** but the **Restaurant is running on ground & 1<sup>st</sup> floor only** was granted NOC by this department vide letter No.F6/MS/DFS/EH/2010/147 dated **13/01/10** The premises was re-inspected by the officer concerned of this department on **01/05/13** in the presence of **Mr. Pankaj Bharadwaj** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – D Assembly Building** with effect from ~~15/5/2013~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 subject to conditions printed below.

Issued 15/5/2013 at New Delhi by.

  
(Dr.G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service

o/d

Copy to:- (1) Dy. Health Officer,  
MCD, South Zone, Green Park, New Delhi.

(2) The Big Chill Cafe Pvt. Ltd.,  
Shop No. 122,272-274,DLF Place Saket,New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



-113

INSPECTION REPORT

1. Name & address of the building:- The Big Chill Cafe Pvt. Ltd., Shop No. 122,272-274, DLF Place Saket, New Delhi.
2. Type of occupancy:- Group – D Assembly Building (Eating House)
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/MS/DFS/EH/2010/147 dated 13/01/10.
5. Fire safety directives No.- No
6. Date of inspection:- 01/05/13.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. Pankaj Bharadwaj
9. Year of construction:- Not known
10. Applicant's letter No:- Nil. dated 22/04/13 3 Basement, Ground + 2 Upper Floors. **The Restaurant is running on ground & 1<sup>st</sup> floor only**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Old Case Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Existing in mall	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	Provided & maintained by mall management	Provided & maintained by mall management	MR
	2. Basements	----do-----	----do-----	----do-----
	B. Width of staircase			
	1. Upper floors	----do-----	----do-----	----do-----
	2. Basements	----do-----	----do-----	----do-----
	C. Protection of exits			
	1. Fire check door	Yes	Provided	MR
	2. Pressurization	Yes	Provided	MR
	D. No. of continuous staircase to terrace	Required	Provided	MR
	E. Width of corridor	1.5 mtr.	Yes	MR
	F. Door size	Required	1.5 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Yes	Provided	MR
	2) Sealing of electrical shafts	Yes	Provided	MR
	3) Fire rating of shaft door	Yes	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	07 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR



	3) ISI marking	Yes	MR
6.	<b>First-Aid Hose Reel</b>		
	1) Total number of each floor	Maintained by mall	2 Nos. near to restaurant
	2) Length of hose reel hose	30 m	Yes
	3) Nozzle diameter	5 mm	Yes
7.	<b>Automatic Fire Detection &amp; Alarming System</b>		
	1) Type of detectors	Provided & maintained by mall management	Provided & maintained by mall management
	2) Location of main panel	-----do-----	-----do-----
	3) Location of repeater panel	-----do-----	-----do-----
	4) Alternate source of power	-----do-----	-----do-----
	5) Hooter's Location	-----do-----	-----do-----
8.	<b>MOEFA</b>	Required	Provided
9.	<b>Public Address System</b>	Provided & maintained by mall management	Provided
10.	<b>Automatic Sprinkler System</b>		
	1) Basement	Yes	Provided
	2) Upper floors	Yes	Provided
	3) Sprinkler above false ceiling	Yes	Provided
11.	<b>Internal Hydrants</b>		
	1) Size of riser/down-comer	Provided & maintained by mall management	Provided & maintained by mall management
	2) Number of hydrants per floor	-----do-----	-----do-----
	3) Hose box	-----do-----	-----do-----
12.	<b>Yard Hydrants</b>		
	1) Total number of hydrants	Provided & maintained by mall management	Provided & maintained by mall management
	2) Hose box	-----do-----	-----do-----
13.	<b>Pumping Arrangement</b>		
	1) Ground level	Provided & maintained by mall management	Provided & maintained by mall management
	a) Discharge of main pump	-----do-----	-----do-----
	b) Head of main pump	-----do-----	-----do-----
	c) Number of main pump	-----do-----	-----do-----
	d) Jockey pump out put	-----do-----	-----do-----
	e) Jockey pump head	-----do-----	-----do-----
	f) Stand by pump output	-----do-----	-----do-----
	g) Stand by pump head	-----do-----	-----do-----
	h) Auto starting/Manual stopping	-----do-----	-----do-----
	2) Terrace level		
	a) Discharge of pump	-----do-----	-----do-----
	b) Head of pump	-----do-----	-----do-----

*Handwritten signature*



	c) Power supply	----do-----	----do-----	----do-----
	d) Auto starting of pump	----do-----	----do-----	----do-----
<b>14.</b>	<b>Captive Water Storage for Fire Fighting :- Provided &amp; maintained by mall</b>			
	1) Under ground tank capacity	Provided & maintained by mall management	Provided & maintained by mall management	MR
	a) Draw-off connection	----do-----	----do-----	----do-----
	b) Fire service inlet	----do-----	----do-----	----do-----
	c) Access to tank	----do-----	----do-----	----do-----
	d) Over head tank capacity	----do-----	----do-----	----do-----
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	Yes	Provided	MR
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Yes	Provided	MR
	d) Fireman's switch	Yes	Provided	MR

	e) Lift signage	Yes	Provided	MR
<b>17.</b>	<b>Stand by Power Supply</b>	Yes	Provided	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	2 <sup>nd</sup> floor	Provided	MR
<b>19.</b>	<b>Fire Control Room</b>			
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	Yes	Provided	MR
	c) PA system panel	Yes	Provided	MR
	d) Battery backup	Yes	Provided	MR
	e) Building floor plan	Yes	Provided	MR
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- Dharampal Bharadwaj

Name: S.S.Kaushik. 07/5/13

Designation:- Divisional Officer

Designation: - Assistant Divisional Officer.