

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/2013/327

Dated: 17/05/2013

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary Girls School**, is comprised of **Ground Only (Sheds)** located at **E-Block, Kamla Nagar, Delhi.-110007** owned / occupied by **MCD Primary Girls School** has already been issued fire safety certificate **Vide letter no F-6/DFS/MS/09/3283 Dated 06/11/2009** have complied with the fire prevention and fire safety requirements in accordance with **Circular dated 17/01/2005** issued by **Director of Education and verified by the officer concerned of Fire Service on 15/04/2013** in the presence of **Mrs. Rose Hemlata (Principal)** and that the building the premises is fit for occupancy of **Group Class B (Educational)** with effect from 17/05/2013 for a period of **three years**, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 17/05/2013 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dfire@nic.in

Copy to:

1. The Principal, MCD Primary Girls School, E-Block, Kamla Nagar, Delhi.-110007
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi



2/2

INSPECTION REPORT

1. Name & address of the building MCD Primary Girls School, E-Block, Kamla Nagar - Educational - Delhi - 7
2. Type of Occupancy Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFs/ms/09/3283 Dated: 6-11-2009
5. Fire Safety directives letter No Circular Dir. of Edun. 17-1-2005.
6. Date of inspection : 15-4-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAJ
8. Name and designation of officers Mr. Rose Hemlata Soresng
from the building side :
9. Year of Construction 1962, (Ground, Sheds)
10. Applicant's letter No. NIL dated 4-3-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edun. Requirement 17/1/2005</u> Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	<u>Accessible 6 m</u>	<u>MSR</u>
	• Gate width	<u>5 m</u>	<u>MSR</u>
	• Width of internal road	<u>NIA</u>	<u>NIA</u>
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	<u>NIA</u>	
	• Upper Floors		
	• Basements		
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits		
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace		
	g. Width of Corridor		
	h. Door Size	<u>1 m</u>	<u>1.06 m MSR (one door) Less than 1.5 m.</u>
3	Compartmentation.		
	• Fire check door	<u>NIR</u>	
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	<u>30 a/c per hour</u>	<u>MSR</u>
	• Upper floors	<u>12 a/c per hour</u>	

MB

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>2 ABC ISI marked</p>	<p>Provided</p> <p>-n-</p> <p>-n-</p>	<p>m/r</p> <p>m/r</p> <p>m/r</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m</p> <p>5 mm</p>	<p>NIR</p> <p>/</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		<p>NIR</p> <p>/</p>	
8	MOEFA			
				NIR
9	Public Address System.			
				NIR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		<p>NIR</p> <p>/</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		<p>NIR</p> <p>/</p>	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		<p>NIR</p> <p>/</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		<p>NIR</p> <p>/</p>	

1/1/1

2/14

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 			NIR
15	Exit Signage.			NIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 			NIA
17	Standby power supply			NIR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			NIA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 			NIR
20	Special Fire Protection Systems for Protection of special Risks, if any:	—		Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

DO. (NW)

SHYAM LAL

Designation

Designation

Genl

Assist. Divn. officer

cto 4/6/15

Shyam Lal 20/4/2013