

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfhq.dlfire@njc.in

No F6 / DFS / MS / 2013 / 269

Dated 7/5/2013

FIRE SAFETY CERTIFICATE

Certified that the Poorva Shanskriti Kendra at plot No. 14, Distt. Centre Laxmi Nagar Delhi. which comprises of basement, ground & two upper floors was granted NOC by this deptt. vide letter No. F6 / DFS / MS / 2009 / 1494 dated 28-05-2009. The premises was re-inspected by the officer concerned of this department on 09-04-2013 in the presence of Mr. Ghai and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from - - 2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on at New Delhi.

(DR. G.C.MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. 23414333

Copy to:-

1. The Asstt. Commissioner (Clubs)
GNCTD, L & N Block,
Vikas Bhawan, I. P. Estate,
New Delhi.
2. The Gernal Manager
Poorva Shanskriti Kendra
at plot No. 14, Distt. Centre
Laxmi Nagar Delhi.

9c

5/5/13

Condition

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basements shall be used as per BBL
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

INSPECTION REPORT

1. Name & address of the building: Poorva Sanskriti Kendra 14, Distt. Centre, Laxmi Nagar, Delhi.
2. Building is comprised of : Basement, Ground + 2
3. Type of Occupancy : Club (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC letter: F6/MS/DFS/2009/1494 dated 28.5.2009
6. Fire Safety direction letter No : NA
7. Date of Inspection : 09.04.2013
8. Name of the Inspecting officers: Gurmukh Singh
9. Name and designation of Officer: Sh. D.S.Ghai (GM)
from the building side
10. Year of Construction : 2003
11. Applicant's letter No : -Nil- dated 03.01.2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Existing/ Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtr	24 Mtr	MR
	• Gate width	5.0 Mtr	5.0 Mtr	MR
	• Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	• Upper Floor	2Nos	2Nos	MR
	• Basement	2Nos	2+2ramp	MR
	B. Width of Staircases			
	• Upper Floor	Existing	2.0Mtr&1.20Mtr.	MR
	• Basement	Existing	1.5&1.2Mtr	MR
	c. Protection of exits			
	• Fire check door	NA	NA	
	• Pressurization	NA	NA	
	e. No. of continuous staircases to terrace	2Nos	2Nos	MR

	g. Width of Corridor h. Door Size	1.5 Mtr.	1.5 Mtr	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	NA	NA	
	• Water curtain	NA	NA	
	• Fire Dampers	NA	NA	
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor
5.	Fire Extinguishers			
	• Total numbers	22Nos.	25Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	2Nos	2Nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat/smoke	Heat & smoke	MR
	• Location of main panel	Basement	Basement	MR
	• Location of repeater panel	NA		
	• Alternate source of power	Reqd.	Provided	MR
	• Hooter's location
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	Required	Provided	MR
	• size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	2 Nos.	2Nos.	MR
	• Hose Box	2 Nos	2 Nos	MR

12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	• Ground Level
	➤ Discharge of main Pump	2850 LPM.	2850 LPM	MR
	➤ Head of Main Pump	52 Mtrs.	52 mtrs	MR
	➤ Number of main pumps	2 Nos	2 Nos.	MR
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	56 Mtrs.	56 mtrs.	MR
	➤ Standby pump out put	2850 LPM	2850 LPM	MR
	➤ Standby pump Head	52Mtrs	52 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Available	MR
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.
	• Underground tank capacity	1,00,000Ltr	1,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000Ltr.	10,000Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	MR
	• Pressurization of Lift Shaft	NA	NA	
	• Pressurization of Lift lobby	NA	NA	
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	NA	NA	
	• Total area	NA	NA	
	• Location	NA	NA	

-N/27-

19	Fire Control Room	Required	Provided	MR
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name

Designation

Gurpreet Singh
9/11/13
Gurpreet Singh
ADD (2N)