

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/school/2013/323

Dated: 16/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Rose Diamond Public School, is comprised of Ground only located at Jain Nagar, Karala, Delhi-110081 has already been issued fire safety certificate vide letter no. F-6/MS/DFS/08/1660 Dated 18/06/2008 have complied with the fire prevention and fire safety requirements in accordance with Circular dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 16/04/2013 in the presence of Smt. Prabha and that the building the premises is fit for occupancy of Group Class B (Educational) with effect from 16/05/2013 for a period of three years, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 16/05/13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

Copy to:

1. The Principal, Rose Diamond Public School, Jain Nagar, Karala, Delhi 110081.
2. The Addl. Director (Edmn) NMCD, Civic Center N.Delhi.

NH  
Renewal School

INSPECTION REPORT

1. Name & address of the building: Rose Diamond Public School, Jain Nagar, Delhi
2. Type of Occupancy: Educational
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. F-6/MS/DFS/08/1460 Dated: 18-6-2008
5. Fire Safety directives letter No: Circular, Director of Edn. 17/05.
6. Date of inspection: 16-4-2013
7. Name of the Inspecting Officers: ADO-SHYAM LAL
8. Name and designation of officers from the building side: Ms. Prabha.
9. Year of Construction: 2001 (Ground only)
10. Applicant's letter No.: NIL dated 1-4-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	Accessible 6 m	MIR
	• Gate width	- - -	MIR
	• Width of internal road	NIA	MIR
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	NIA	
	• Upper Floors		
	• Basements		
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits		
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace		
	g. Width of Corridor		
	h. Door Size	1 m	1.05 m MIR
3	Compartmentation.		
	• Fire check door		MIR
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	MIR
	• Upper floors	12 a/c per hour	

Circular, Dir. of Edn. 17/1/2005

(Old Case)

N/D

5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	02 ABC ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m 5 mm	NIR	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		NIR	
8	MOEFA		NIR	
9	Public Address System.		NIR	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		NIR	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		NIR	

M

N/h

14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>				NIR
15	Exit Signage.				NIR
16	Provision of Lifts.				
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>				N/A
17	Standby power supply				N/A
18	Refuge Area.				
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>				N/A
19	Fire Control Room				
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>				NIR
20	Special Fire Protection Systems for Protection of special Risks, if any:				
					Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*Shyam Lal*  
DO. (NW)  
25/4/13

*Shyam Lal*  
20/4/2013  
SHYAM LAL  
Assist. Divn. Officer