

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Fax: 23412593, E-mail: cfohq.dlfire@nic.in

No. *F6/DFS/ms/school/2013/343*

Dated: *21/05/13*

FIRE SAFETY CERTIFICATE

Certified that the **Sneh International School** at New Rajdhani Enclave, Vikas Marg, Delhi-92. Comprised of basement ground plus two upper floors owned/occupied by Sneh International School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 14.05.13 in the presence of Sh.Subhash Dhingra, President, of the school and that the building is fit for occupancy class B' Educational Building' with effect from *21/05/13* for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....*21/05/13*.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph.23414333

To,
Sh.Subhash Dhingra (President)
Sneh International School
New Rajdhani Enclave,
Vikas Marg, Delhi-92.

Copy:-
The Director of Education
Directorate of Education,
Lucknow Road, Delhi -54.

*Dr
Real
20.5.13*

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per B.B.L.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Sneh International School at New Rajdhani Enclave, Vikas Marg, Delhi -110092.
2. Building is comprised of : Basement, Ground +2, upper floors.
3. Type of Occupancy : Educational
4. Type of Case : New Case *as building floors changed.*
5. Details of Previous NOC letter : F.6/MS/DFS/06/184 dated 19.01.06 for G+2 floor *only.*
6. Fire Safety direction letter No : NBC
7. Date of Inspection : 14.05.13
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:
 from the building side : Sh. Subhash Dhingra (President)
10. Year of Construction - : 2004 -2012
11. Applicant's letter No : SIS/2012-13/738 dated 20/03/13.

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 Mtrs.	15 Mtrs.	MR
		4.5 M	Provided	MR
		-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 Nos	02 Nos.	MR
		02 Nos	02 Nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M	1.5 M	MR
		1.5 M	1.5 M	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-----	-----	-----
		-----	-----	-----
	e. No. of continuous staircases to terrace			
		1 Nos.	2 Nos.	MR
	g. Width of Corridor			
		1.5 mts.	2.0 mts	MR
	h. Door Size			
		1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----

Sneh International School at New Rajdhani Enclave, Vikas Marg, Delhi.

4	Smoke Management System.			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5.	Fire Extinguishers			
	• Total numbers	16 Nos.	16 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	2 Nos.	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 MM	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	• Hooter's location	-----	-----	-----
8	MOEFA			
9	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants			
	• size of riser/down-comer	Not Required	100 MM	Acceptable
	• Number of hydrants per floor	Not Required	2 Nos.	Acceptable
	• Hose Box	Not Required	2 Nos.	Acceptable
12	Yard Hydrants.			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----

Sneh International School at New Rajdhani Enclave, Vikas Marg, Delhi.

	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	2 nos. of 450 LPM <i>each</i>	1 no.of 450 LPM, 1no.of 950 LPM	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.	-----	-----	-----
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	-----	-----	-----
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	-----	-----	-----
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire extinguishers provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name VIRENDRA SINGH

Designation

DO (E)

CFO

[Handwritten signature]

