

10/c

10/c

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/school/2013/350

Dated: 22/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the St. John Mary Vianney School Gail No. 10 Sanjay Colony, Narela, Delhi. is comprised of Basement, Ground + One Upper Floor & a hall on G.F owned and occupied by St. John Mary Vianney School, have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 11/04/2013 in the presence of Fr. Kulandai Samy and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 22/05/2013 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 22/05/2013 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Principal, St. John Mary Vianney School Gail No. 10 Sanjay Colony, Narela, Delhi.
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

- M7
1. Name & address of the building: St. John Marys Vianney School, Gali No. 10
  2. Type of Occupancy: Educational
  3. Type of Case: New Case/ Renewal
  4. Details of previous NOC: Letter No. NIL Dated: \_\_\_\_\_
  5. Fire Safety directives letter No: Circular, Dir. of Edun. 1/3/2011
  6. Date of inspection: 11-4-2013
  7. Name of the Inspecting Officers: ADO - SHYAM LAL
  8. Name and designation of officers from the building side: Fr. Kulanjai Sany. (Principal)
  9. Year of Construction: 2006, (Ground + one upper floor & - Basement)
  10. Applicant's letter No.: NIL dated 21-3-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building	<u>Circular Dir. of Edun. 1/3/2011</u>		
	• Road width	<u>Accessible</u>	<u>5 m</u>	<u>MIR</u>
	• Gate width	<u>- do -</u>	<u>3 m x 2</u>	<u>MIR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>04</u>	<u>04</u>	<u>MIR</u>
	• Upper Floors	<u>02</u>	<u>02</u>	<u>MIR</u>
	• Basements	<u>02</u>	<u>02</u>	<u>MIR</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.41 m &amp; 1.35 m</u>	<u>MIR</u>
	• Basements	<u>1.5 m</u>	<u>1.41 m each</u>	<u>MIR</u>
	c. Protection of exits			
	• Fire check door		<u>NIR</u>	
	• Pressurization		<u> </u>	
	e. No. of continuous staircases to terrace	<u>R</u>	<u>2</u>	<u>MIR</u>
	g. Width of Corridor	<u>R</u>	<u>2.8 m</u>	<u>MIR</u>
	h. Door <u>width</u>	<u>1 m</u>	<u>1.51 m</u>	<u>MIR</u>
3	Compartmentation.			
	• Fire check door		<u>NIR</u>	
	• Sealing of electrical shafts		<u> </u>	
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	<u>30 a/c per hour</u>	<u>NIR</u>	
	• Upper floors	<u>12 a/c per hour</u>	<u> </u>	

as per D.O.E. Circular of 1-3-11.

5	Fire Extinguishers		
	• Total numbers	12	20
	• Types	ABC/CO2 (ISI marked)	ABC/CO2
	• IS marking		yes
			MIR
			MIR
			MIR
6	First-Aid Hose Reels.		
	• Total numbers on each floor	NIR	one at each floor
	• Length of hose reel hose	30 m	provided
	• Nozzle diameter	5 mm	provided
			MIR
			MIR
7	Automatic fire detection and alarming system.		
	• Type of detectors		NIR
	• Location of Main Panel		
	• Location of Repeater Panel		
	• Alternate source of power		
	• Hooters' Location		
8	MOEFA		
			NIR
9	Public Address System.		
			NIR
10	Automatic Sprinkler System.		
	• Basement	R	provided
	• Upper Floor	NIR	NIP
	• Sprinkler above false ceiling	NIR	NIP
			NIA
			NIA
11	Internal Hydrants		
	• Size of riser/down-comer		NIR
	• Number of hydrants per floor		
	• Hose Box		
12	Yard Hydrants.		
	• Total number of hydrants		NIR
	• Hose Box		
13	Pumping Arrangements.		
	• Ground Level		NIR
	• Terrace level		
	• Discharge of main Pump		
	• Head of Main pump		
	• Number of main pumps		
	• Jockey Pump out put		
	• Jockey pump head		
	• Standby Pump out put		
	• Standby Pump Head		
	• Auto Starting/ Manual stopping		
	• Pump House Access		
	• Discharge of pump	450 Lts/minute	provided
	• Head of the pump	40 m	provided
	• Power Supply	NIR	NIP
	• Auto Starting of pump	R	provided

14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>				
		5000 LBS.	Provided		NIR
15	Exit Signage.				NIR
16	Provision of Lifts.				NIA
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>				
17	Standby power supply				NIR
18	Refuge Area.				NIA
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>				
19	Fire Control Room				NIR
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>				
20	Special Fire Protection Systems for Protection of special Risks, if any:	—			NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

N/A

NIR

NIA

NIA

NIR

NIL

*[Signature]*  
15/11/2013

SHYAM LAL

DO. (NW)

Assist. Divn. officer

