

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2013/ 376

Dated: 24/5/13

FIRE SAFETY CERTIFICATE

Certified that the building of **M. C. Primary School**, Issa Pur, New Delhi -110073 comprised of ground floor plus one upper floor, having total 09 rooms (Including Class Rooms, Hall & Office etc.) owned/occupied by MCD was inspected by the officer concerned of this department on 08.05.2013 in the presence of Sh. Rajbir Singh (Principal) and found that the M.C.D have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 24/5/13.....at New Delhi


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to: -

1. The Principal,
M. C. Primary School,
Issa Pur, New Delhi-110073.
2. Director of Education,
South Delhi Municipal Corporation
23rd floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/3

Ground Floor + Plus One Upper Floor

INSPECTION REPORT

1. Name & address of the building: M.C. Primary School, Issacpur, N.D. 73.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Dated _____
5. Fire Safety directives letter No : N/A
6. Date of inspection : 08.05.2013
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Rajbir Singh (Principal)
9. Year of Construction : 2008-09
10. Applicant's letter No. : Nil dated 26.03.2013

No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	09mtr	MR
	• Gate width	-	440cm	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-	-	No Basement
b.	Width of staircases			
	• Upper Floor	150cm	168cm, 92cm	MR
	• Basements	-	-	No Basement
c.	Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
d.	No. of continuous staircases to terrace	-	-	-
e.	Width of Corridor	-	220cm	-
f.	Door Size	-	95cm x 207cm	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

N/4-

	12 a/c per hour		
5.	Fire Extinguishers		
	• Total numbers	OS Nos	Provided
	• Types	CO ₂ , ABC	- do - MR
	• IS marking	ISI marked	ISI Marked MR
6.	First-Aid Hose Reels		
	• Total numbers on each floor		
	• Length of hose reel hose	30 m	
	• Nozzle diameter	5 mm	
7.	Automatic fire detection and alarming system		
	• Type of detectors		
	• Location of Main Panel		
	• Location of Repeater Panel		
	• Alternate source of power		
	• Hooters' Location		Near office
8.	MOEFA		
9.	Public Address System		
10.	Automatic Sprinkler System		
	• Basement		No Basement
	• Upper Floor		
	• Sprinkler above false ceiling		
11.	Internal Hydrants		
	• Size of riser/down-comer		
	• Number of hydrants per floor		
	• Hose Box		
12.	Yard Hydrants		
	• Total number of hydrants		
	• Hose Box		
13.	Pumping Arrangements		
	• Ground Level		
	• Discharge of main Pump		
	• Head of Main pump		
	• Number of main pumps		
	• Jockey Pump out put		
	• Jockey pump head		
	• Standby Pump out put		
	• Standby Pump Head		
	• Auto Starting/Manual stopping		

?

in

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	-	Provided	-
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/B-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Note:- The school building is comprised of Ground floor plus one upper floor. The upper floor is served by two staircases having width 168cms & 92cms respectively. The building is directly approachable to the fire engine. There are total 09 rooms including class rooms, Hall & Office etc. The NCD rectify all the shortcomings which are raised vide letter no. F.6/DFS/MS/2012/School/3431 dated 20.09.2012.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation