

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2013/366

Dated: 24/05/2013

FIRE SAFETY CERTIFICATE

Certified that the **N.C. Jindal Public School** (name of the building or premises) located at **Road No. 73, Punjabi Bagh, New Delhi – 110026** and consist of Ground + two upper floors + Auditorium on ground floor have complied with the fire prevention and fire safety requirements in accordance with Director of education circular dated 01/03/2011 and verified by the officer concerned of Fire Service on 22/03/2013 in the presence of **Mr. Shanti Matta (Caretaker)** and the building/premises is fit for occupancy **Educational** with effect from 24 / 05 /2013 for a period of **three years** subject to conditions printed below.

Issued on 24/05/2013 at New Delhi.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel No. - 23414250
Email-cfowz.dlfire@nic.in

Copy to:

1. The Administrator, N C Jindal Public School, Punjabi Bagh, New Delhi.-110026
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

RE-INSPECTION REPORT

1. Name & address of the building : N.C.Jindal Public School, Punjabi Bagh, New Delhi.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : Nil
6. Date of inspection : 12/04/2013
7. Name of the Inspecting Officers : ADO S K Dua
8. Name and designation of officers
from the building side : Sh. Shanti Matta
9. Year of Construction : 1968
10. Applicant's letter No. : NCJPS/113547/2013 Dated 02/03/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <i>D.O.E circular issued on 01/03/2011</i>	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases	1.5 mtrs, if width of the main staircase is less than 1.5 mtr then additional staircase not less than 0.75 mtr shall be provided.	<ul style="list-style-type: none"> 1) 1.42 mtr. 2) 1.22 mtr. 3) 1.37 mtr. 4) 1.37 mtr. 	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			

- M/10 -

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked		
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 			

	<ul style="list-style-type: none"> • Number of hydrants per floor • *Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 			

- M/12

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....


Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO(wr)

Signature of the Inspecting Officer

Name

Designation

