

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/SH/2013/353

Dated: 23/05/2013

FIRE SAFETY CERTIFICATE

Certified that the Night Fever (name of the building or premises) located at Ground Floor, F-1,2 & 3, North Square Mall, Neta Ji Subash Place was issued NOC vide this department letter no.F.6/DFS/MS/2010/3176 dated 15/11/10. The premises was re-inspected by the officer concerned of this department on 30/04/2013 in the presence of Sh. Manoj Sharma and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The building/ premises is fit for occupancy Class D, Assembly with effect from 23/05/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on 23/05/13 at New Delhi.


(CHIEF FIRE OFFICER)
DELHI FIRE SERVICE

Tel:- 011-23414250

Email: - cfowz.dlfire@nic.in

Copy to:

The Authorized Signatory, Night Fever (G-1- G-2), F-1,F-2, & F-3, Neta Ji Subash Place, New Delhi.

Following fire safety directives must be adhered to

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by occupants in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. Basement shall be used as per NBC.
6. This report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in



9810069363

Manoj Sharma

1/1-3

Ground floor only

INSPECTION REPORT

1. Name & address of the building : Night Fever (G1-G-2), F-1,2&3, North Square Mall, N.S. Place.
2. Type of Occupancy : Assembly
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F-6/MS/MS/2010/3176 Dated: 15/11/10
5. Fire Safety directives letter No : _____
6. Date of inspection : 30/4/2013
7. Name of the Inspecting Officers : DO (W) & ADO W/P
8. Name and designation of officers from the building side : Sh. Manoj Sharma
9. Year of Construction : 2006
10. Applicant's letter No. : nil dated 24/4/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	Required	on main road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	Required	open Hall,	MR
	h. Door Size	old case	1.0 mtr x 2 0.95 mtr x 1	old case MR

N-4

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
			N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA Provided (Exhaust)	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types CO_2 4.5kg & ABC-5kg • IS marking 	4 ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels. Common with shopping mall			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system. (with S/mall)			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke/heat N/A NA NA NA	Provided Provided NA NA NA	MR MR NA NA NA
8	MOEFA Common with S/mall	Required	Provided	MR
9	Public Address System. Common with S/mall	NR	Provided	MR
10	Automatic Sprinkler System. Common with shopping mall			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA Required NA	NA Provided NA	NA MR NA
11	Internal Hydrants Common with shopping mall			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	100 mm	MR

N-5

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	NR	one	MR	
		NR	one	MR	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A		
13	Pumping Arrangements. <i>Common with Small</i>				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NR	2850 LPM	Provided	MR
		NR	60 mts.	Provided	MR
		NR	one	Provided	MR
			180 LPM	Provided	MR
			60 mtr	Provided	MR
		NR	2850 LPM	Provided	MR
			Auto	Provided	MR
		NR		P	MR
			N.R.	NR	NR
			"	"	"
			"	"	"
			"	"	"
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NR	1,00,000 Lts.	MR	
		NR	Provided	MR	
		NR	Provided	MR	
		NR	Provided	MR	
		30,000	Provided	MR	
15	Exit Signage.	R	P	MR	
16	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 		N/A		

NR

N-6

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply	R	P	mx
18	Refuge Area.			
	➤ Total Area		N/A	
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

S.K. Dua

Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Sumil chawdhary

Signature of the Inspecting Officer

Name Sumil chawdhary

Designation DO (W)

