

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/2013/ 364

Dated: 24/05/13

FIRE SAFETY CERTIFICATE

Certified that the **Westend Mall** located at District Center, Janak Puri, New Delhi-110058 comprised of Lower Basement, Upper Basement, Ground Floor plus ten upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/2009/1480 dated 26.05.2009 owned/occupied by the P.P. Build Well Pvt. Ltd. The Mercantile building was re- inspected by the officers concerned of this department on 13.05.2013 in the presence of Sh. Gopal Parsad (Accountant), Sh. K.S. Misra (Fire Head) and found that the P.P. Build Well Pvt. Ltd have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group F mercantile building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....24/05/13.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Authorized Signatory,
P.P Build Well Pvt. Ltd.,
A-107, North Ex Mall, Sec-9,
Rohini, New Delhi-110085.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Lower Basement, Upper Basement, Ground Floor plus ten upper floors.

INSPECTION REPORT

1. Name & address of the building : Westend Mall, District Center, Janak Puri, N.D-58.
2. Type of Occupancy : Mercantile
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/09/1480 Date 26.05.2009
5. Fire Safety directives letter No : F.6/MS/DFS/BJ/2005/1178 dated 07.06.2005
6. Date of inspection : 13.05.2013
7. Name of Inspecting Officer : D.O H.L. Anepai & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Gopal Parbad & Sh. K.C. Mishra
9. Year of Construction : 2006-07
10. Applicant's letter No. : Nil dated 22.04.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>-</p> <p>-</p>	<p>18 mtr</p> <p>05 mtr</p> <p>-</p>	<p>MR</p> <p>MR (Old Case)</p> <p>-</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>Five</p> <p>Eight, 01 Ramp</p>	<p>Five</p> <p>Eight, 01 Ramp</p>	<p>MR</p> <p>MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>-</p> <p>-</p>	<p>147, 148, 126, 126 122 cms</p> <p>150, 144, 128, 93 125 cms Each (04 case)</p>	<p>MR (Old Case)</p> <p>- do -</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>Required</p> <p>-</p>	<p>Provided</p> <p>-</p>	<p>MR</p> <p>-</p>
	d. No. of continuous staircases to terrace			
		-	Four	-
	e. Width of Corridor			
		-	300 cms, 194 cms	-
	f. Door Size			
		-	255 cms x 230 cms	-
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>Required</p> <p>- do -</p> <p>01 Hr</p> <p>-</p> <p>Required</p>	<p>Provided</p> <p>Sealed</p> <p>01 Hr</p> <p>-</p> <p>Provided</p>	<p>MR</p> <p>MR</p> <p>MR</p> <p>-</p> <p>MR</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p>	<p>Mechanical Ventilation system</p> <p>-</p>	<p>MR</p> <p>-</p>

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	12 Nos at each floor	Provided	MR
	• Types	CO ₂ , WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Four	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Smoke	MR
	• Location of Main Panel	-	Near main gate	MR
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	Required	03 D.G. Set of 500kVA Each	MR
	• Hooters Location	-	-	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	- do -	- do -	MR
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	150 M.M	150 M.M	MR
	• Number of hydrants per floor	Four	Four	MR
	• Hose Box	- do -	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	Four	Four	MR
	• Hose Box	- do -	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	4500 LPM	4500 LPM	MR
	➤ Head of Main pump	70 M	70 M	MR
	➤ Number of main pumps	Two	Two	MR
	➤ Jockey Pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70 M	70 M	MR
	➤ Standby Pump out put	4500 LPM	4500 LPM	MR
	➤ Standby Pump Head	70 M	70 M	MR
	➤ Auto Starting/Manual stopping	Both	Both	MR

District Center, Janak Puri,
New Delhi - 110058.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	Required	Provided	MR
		-	-	-
		-	-	-
		-	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	200000 Ltr	200000 Ltr	MR
		Required	Provided	MR
		- do -	- do -	MR
		- do -	- do -	MR
		30000 Ltr	30000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Required	Provided	MR
		- do -	- do -	MR
		- do -	- do -	MR
		- do -	- do -	MR
		- do -	- do -	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	2.56 sq.m	MR
		-	5 th , 7 th & 9 th floor	MR
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	Provided	MR
		-	-	-
		-	Provided	-
		-	- do -	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

Note: The Westend Mall Building issued NOC by this department vide letter No. F.6/DFS/MS/09/1480 dated 26.05.2009 and same is renewed.


Signature of Inspecting Officer

Name H. L. Aneja
Designation Divisional Officer


Signature of Inspecting Officer

Name P. S. Dahiya
Designation A&H. Divisional Officer.