

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Ph - 23414333 Fax - 23412593 Email - cfhq.dfire@nic.in

No. 66/OFS/MS/2013/396

Dated: 30/05/13

FIRE SAFETY CERTIFICATE

Certified that the Ashirwad Banquet, (banquet hall running at ground and first floors) Property No. 486/2, Jheel Khurenja, Delhi-51, comprised of ground plus two upper floors owned/occupied by M/S Ashirwad Barat Ghar, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on dated 08.05.13 in the presence of Mr. Satya Prakash Attri, Owner and that the building is fit for occupancy class D 'Assembly (Banquet Hall)' with effect from ..30/05/13.. for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on...30/05/13.....at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Dr
Real
30.5.13

Copy to-

1. The Dy. Health Officer,
MCD Health Department,
Shahdara (South) Zone, 5th Floor, Karkardooma, Shahdara, Delhi
2. Shri Satya Prakash Attri,
Ashirwad Barat Ghar Property No. 486/2, Jheel Khurenja, Delhi-51.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Ashirwad Banquet, Property No. 486/2, Jheel Khurenja, Delhi-51.
2. Building is comprised of : G+2 (banquet hall running at G+1 and 2nd floor used as a resident)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/880 dated 01.03.13
7. Date of Inspection : 08.05.13
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer
from the building side : Mr. Satya Prakash Attri, Owner
10. Year of Construction : 1994
11. Applicant's letter No : Dated 22.04.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	17 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	02 no.	MR
	Upper Floor
	Basement
	b. Width of Staircases	1.5 m	1.5 m, 1.6 m ✓	MR
	Upper Floor	1.5 m	1.5 m, 1.6 m ✓	MR
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace	01 no.	01 no.	MR ✓
	g. Width of Corridor
	h. Door Size	2 m	2.3 m, 2 m, 1.8 m	MR ✓
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System. Ventilated			
	Basement	30a/c per hour	Ventilated
	Upper floor	12 a/c per hour	Ventilated

2/4

5.	Fire Extinguisher	Required	Provided	
	Total numbers	06 no.	06 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers	03 no.	03 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system. N/A			
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	Required	Provided	
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants	03 no.	03 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	Required	Provided	
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump
	➤ Head of the Pump	450 LPM	450 LPM	MR
	➤ Power supply	40 m	40 m	MR
	➤ Auto Starting of pump
	

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity	15,000 Liters	15,000 Liters	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	Yes
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *AO*

