

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax : 011-23412593 E-mail : cfohq.dlfire@nic.in Ph. 011-23414333.


No.F6/DFS/MS/EH/2013/ 389

Dated : 29/5/13

FIRE SAFETY CERTIFICATE

Certified that the **Lotus Garden Restaurant** located at **SF-9, Bhikaji Cama Bhawan, Bhikaji Cama Place, New Delhi-110066** comprised of **Basement, Ground + 10 Upper Floors but the Restaurant is running on 2nd floor only** was granted NOC by this department vide letter No. **F6/MS/DFS/EH/2010/1032** dated **09/04/10** The premises was re-inspected by the officer concerned of this department on **18/05/13** in the presence of **Mr. Ashok** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – D Assembly Building** with effect from 29/5/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 subject to conditions printed below.

Issued 29/5/13 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The DEO (Restt.)
Office of Commissioner of Ex., Ent. & L. Tax,
L Block, Vikas Bhawan, I.P. Estate, New Delhi.

(2) Lotus Garden Restaurant,
SF-9, Bhikaji Cama Bhawan, Bhikaji Cama Place, New Delhi-110066.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Lotus Garden Restaurant,SF-9,Bhikaji Cama Bhawan, Bhikaji Cama Place,New Delhi-110066.
2. Type of occupancy:- Group – D Assembly Building (Eating House)
3. Type of case:- Renewal
4. Details of previous NOC:-No.F6/MS/DFS/EH/2010/1032 dated 09/04/10.
5. Fire safety directives No.- No
6. Date of inspection:- 18/05/13.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Ashok
9. Year of construction:- Not known
10. Applicant's letter No:-Nil. dated 02/05/13 basement ,ground + 10 upper foors. **The Restaurant is running on 2nd floor only**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	Existing in Building	12 mtr. Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	6 mtr.	6 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Provided & maintained by DDA	Provided & maintained by DDA	MR
	2. Basements	-----do-----	-----do-----	-----do-----
	B. Width of staircase			
	1. Upper floors	-----do-----	2 Nos. available near restaurant	-----do-----
	2. Basements	-----do-----	-----do-----	-----do-----
	C. Protection of exits			
	1. Fire check door	-----do-----	-----do-----	-----do-----
	2. Pressurization	-----do-----	-----do-----	-----do-----
	D. No. of continuous staircase to terrace	Required	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Two door	2 Nos.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers		6 Nos.	MR

Kaushik

	2) Types	ISI Marked	ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Provided & maintained by DDA	2 Nos. near to restaurant	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Provided & maintained by DDA	Provided & maintained by DDA	MR
	2) Location of main panel	----do-----	----do-----	----do-----
	3) Location of repeater panel	----do-----	----do-----	----do-----
	4) Alternate source of power	----do-----	----do-----	----do-----
	5) Hooter's Location	----do-----	----do-----	----do-----
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Provided & maintained by DDA/Bldg. Authority	Provided & maintained by DDA/Bldg. Authority	MR
10.	Automatic Sprinkler System			
	1) Basement	----do-----	----do-----	----do-----
	2) Upper floors	----do-----	----do-----	----do-----
	3) Sprinkler above false ceiling	----do-----	----do-----	----do-----
11.	Internal Hydrants			
	1) Size of riser/down-comer	Provided & maintained by DDA	Provided & maintained by DDA	MR
	2) Number of hydrants per floor	----do-----	----do-----	----do-----
	3) Hose box	----do-----	----do-----	----do-----
12.	Yard Hydrants			
	1) Total number of hydrants	Provided & maintained by DDA	Provided & maintained by DDA	MR
	2) Hose box	----do-----	----do-----	----do-----
13.	Pumping Arrangement			
	1) Ground level	Provided & maintained by DDA	Provided & maintained by DDA	MR
	a) Discharge of main pump	----do-----	----do-----	----do-----
	b) Head of main pump	----do-----	----do-----	----do-----
	c) Number of main pump	----do-----	----do-----	----do-----
	d) Jockey pump out put	----do-----	----do-----	----do-----
	e) Jockey pump head	----do-----	----do-----	----do-----
	f) Stand by pump output	----do-----	----do-----	----do-----
	g) Stand by pump head	----do-----	----do-----	----do-----
	h) Auto starting/Manual stopping	----do-----	----do-----	----do-----
	2) Terrace level			
	a) Discharge of pump	----do-----	----do-----	----do-----
	b) Head of pump	----do-----	----do-----	----do-----

	c) Power supply	----do-----	----do-----	----do-----
	d) Auto starting of pump	----do-----	----do-----	----do-----
14.	Captive Water Storage for Fire Fighting :- Provided & maintained by mall			
	1) Under ground tank capacity	Provided & maintained by DDA	Provided & maintained by DDA	MR
	a) Draw-off connection	----do-----	----do-----	----do-----
	b) Fire service inlet	----do-----	----do-----	----do-----
	c) Access to tank	----do-----	----do-----	----do-----
	d) Over head tank capacity	----do-----	----do-----	----do-----
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Provided & maintained by DDA		
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	Yes	Provided	MR
	c) PA system panel	Yes	Provided	MR
	d) Battery backup	Yes	Provided	MR
	e) Building floor plan	Yes	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- Dharampal Bharadwaj

Name: S.S.Kaushik. 22/11/13

Designation:- Divisional Officer

Designation: - Assistant Divisional Officer.