

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2013/ 398

Dated: 30/05/13

FIRE SAFETY CERTIFICATE

Certified that the **Mamta Modern Sr. Sec. School** located at H Block, Vikas Puri, New Delhi-110018 comprised of Basement, Ground floor plus two upper floors, having total 77 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Sports Room, Library & Store etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/2007/1743 dated 29.06.2007. The School building was re inspected by the officer concerned of this department on 21.05.2013 in the presence of Sh. Ramesh Chand (Admn.) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....30/05/13.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Mamta Modern Sr. Sec. School,
H Block, Vikas Puri, New Delhi-18.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Basement, Ground Floor plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : Mamta Modern Sr. Sec. School, H-Block, Vikas Puri, N.D-18.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F-6/DFS/MS/2007/1743 Date 29.06.2007
5. Fire Safety directives letter No : N/A
6. Date of inspection : 21.05.2013
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers : Sh. Ramesh Chand (Admn.)
From the building side
9. Year of Construction : Before 2006
10. Applicant's letter No. : MMS/600 dated 22.04.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC	Provided at	Remarks
		Requirement	site	
1.	Access to building			MR/NMR
	• Road width	<u>Accessible</u>	<u>09 mtr</u>	<u>MR</u>
	• Gate width	<u>-</u>	<u>390 cms</u>	<u>MR</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>Three</u>	<u>Three</u>	<u>MR</u>
	• Basements	<u>Five</u>	<u>Five</u>	<u>MR</u>
	b. Width of staircases			
	• Upper Floor	<u>-</u>	<u>125 cms Each</u>	<u>MR (old case)</u>
	• Basements	<u>-</u>	<u>320, 197, 136, 133, 100 cms</u>	<u>- do -</u>
	c. Protection of exits			
	• Fire check door	<u>Required</u>	<u>Provided</u>	<u>MR</u>
	• pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	d. No. of continuous staircases to terrace	<u>-</u>	<u>Two</u>	<u>-</u>
	e. Width of Corridor	<u>-</u>	<u>230 cms</u>	<u>-</u>
	f. Door Size	<u>-</u>	<u>112 cms x 210 cms</u>	<u>-</u>
3.	Compartmentation			
	• Fire check door	<u>-</u>	<u>Provided</u>	<u>-</u>
	• Sealing of electrical shafts	<u>-</u>	<u>Sealed</u>	<u>-</u>
	• Fire Rating of shaft door	<u>-</u>	<u>-</u>	<u>-</u>
	• Water Curtain	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Dampers	<u>-</u>	<u>-</u>	<u>-</u>
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	<u>Exhaust Fans are provided</u>	<u>MR</u>
	• Upper floors	<u>-</u>	<u>Natural Ventilation</u>	<u>MR</u>

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Six at each floor	Provided	MR
	• Types	ABC, CO ₂ , WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Three	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 62.5 kVA	MR
	• Hooters' Location	-	-	-
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	One	MR
	• Hose Box	-	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

H Block, Vikas Puri,
New Delhi - 110018

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		450 LPM, 180 LPM	450 LPM, 180 LPM	MR (02 Pumps)
		30m Each	30m Each	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	Provided	-
		-	10000ltr	MR (old case)
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		Required	Provided	MR
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



P. S. Dahiya
27/5/13

Signature of Inspecting Officer

Name *P. S. Dahiya*

Designation *Asstt. Divisional Officer.*

Signature of Inspecting Officer

Name

Designation