

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/2013/FH/409


Dated: 31/05/2013

FIRE SAFETY CERTIFICATE

Certified that the National Farm, located at, Palla Bakhtawarpur Road, Delhi comprised of Ground + one floor is built on a plot area of 3.54 acre land with covered area of approximately 150 square yard is owned / occupied by Sh Ajay Gupta, have complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 02/05/2013 in the presence of Sh Ajay Gupta, and that the building / premises is fit for occupancy Class Sub Div. D-5 Assembly Buildings with effect 31/05/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 31/05 /2013 at New Delhi by



(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
cfowz.dlfire@nic.in
Tel Ph. 23414250

Copy to:

1. Assistant Commissioner (Narela Zone), North Delhi Municipal Corporation, Delhi with reference to letter no. AC/NRZ/2013/490 dated 05/02/2013.
2. Sh Ajay Gupta, National Farm Palla Bakhtawarpur Road, Delhi

May kindly see the letter No AC/NRZ/2013/490 dated 05/02 /2013 received from Assistant Commissioner (MCD), Narela Zone regarding issuance of NOC from fire safety and fire prevention point of view in respect of National farm located at Palla Bakhtawarpur Road, Delhi for holding social function such as wedding and parties etc.

Accordingly the farm house premise was visited and inspected by the undersigned along with Sh Ajay Gupta on dated 02/05/2013 as per Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and it was observed that the farm house is comprised of Ground floor + one upper floor having a total plot area of approx 3.54 acre. The permanent structure covers approximately 150 sq yards.

Remaining portion is open green, temporary shed, parking and road etc. No permanent sitting arrangement was seen at the time of inspection. The premise is approachable from Palla Bakhtawarpur main road of 60 feet. There was no electric over head wiring.

As regards to the fire protection arrangements, the status is as under.

S/NO.	Fire Safety Provision	Provided / Not Provided
1.	Access to building	Accessible & NOC already issued by team
2.	Number, width type and arrangement of exits	- 110 cms - ✓
3.	Protection of exits by means of fire checks door (s) and or pressurization.	N/A
4.	Compartmentation	N/A
5.	Smoke Managements system	N/A
6.	Fire Extinguishers	12 ABC type
7.	Fire Aid Hose Reels	Provided and functional
8.	Automatic Fire detection and alarming system	N/A
9.	MOEFA	Provided and functional
10.	Public Address System	N/A
11.	Automatic sprinkler system	N/A
12.	Internal Hydrants and Yard Hydrants	Provided and functional
13.	Pumping Arrangements 450 LPM / 900 LPM	450 LPM provided.
14.	Captive water Storage for fire 10000 ltr / 15000 ltr	10000 ltr provided
15.	Exits Signage	Provided
16.	Provision of lifts	N/A
17.	Standby power supply	Not required, but found provided ✓
18.	Refuge Area	N/A
19.	Fire Control Room	N/A
20.	Special fire protection systems for protection of special risks	N/A

Case is recommended for function up to 300 persons.