

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2013/411

Dated: 03/06/2013

FIRE SAFETY CERTIFICATE

Certified that the **APS Food Ltd.** Located at Premises No. 28, GF,FF,SF, Adarsh Bhawan Co-op. Society, West Punjabi Bagh, New Delhi-110026. comprised of Basement, ground floor + three upper floors was issued NOC vide this office letter No. **F6/DFS/MS/GH/2010/1370** dated **10/05/2010**. The premises was re-inspected by the officers concerned of this department on **10/05/2013** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-D (Assembly)** occupancy with effect from...03/06/13...for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010. subject to conditions printed below.

Issued on...03/06/13.....at New Delhi by


Chief Fire Officer
Delhi Fire Service
Tel.No.23414250

E-mail- ID-cfowz.dlfire@nic.in

Copy to:

1. Sh. Ashu Taneja , APS Food Ltd., Premises No. 28, GF,FF,SF, Adarsh Bhawan Coo-p Society, West Punjabi Bagh., New Delhi-110026.
2. Dy. Health Officer, MCD West Zone

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N-13

May Kindly peruse letter no. D-2513/HD/WZ dated 10/03/2013 received from DHO West Zone, regarding renewal of NOC in r/o APS Food Ltd. Premises No. 28, NWA Punjabi Bagh Extn., New Delhi-110026. Accordingly premises was inspected & observed that the building comprised Basement, ground floor + three upper floors + terrace. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : APS Food Ltd. Premises No. 28, GF, FF, SF, Adarsh Bhawan Co-op. Society, West Punjabi Bagh, New Delhi-110026.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2010/1370 dated 10/05/2010
5. Fire Safety directives letter No. : nil
6. Date of inspection : 10.05.2013
7. Name of the Inspecting Officers : D.O. (MN)
8. Name and designation of officers
From the building side : Mr. Ashu Taneja
9. Year of Construction :
10. Applicant's letter No. : D-2513/HD/WZ dated 10/03/2013

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09 mtr	12 mtr	M.R. ✓
	• Gate width	Old case	Old case	M.R. ✓
	• Width of internal road	Old case	Old case	M.R. ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R. ✓

17-14

	<ul style="list-style-type: none"> Basement 	2	2	M.R.
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Basement 	Old case	Old case	M.R.
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Pressurization 	Old case	Old case	M.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Old case	Old case	M.R.
	f. Door size	Old case	Old case	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Water Curtain 	Old case	Old case	M.R.
	<ul style="list-style-type: none"> Fire Dampers 	Old case	Old case	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Exhaust fans Fans are provided	M.R.
	<ul style="list-style-type: none"> Upper floors 	required	provided	M.R.

N-15

5.	Fire Extinguishers			
	• Total numbers	12	16	M.R.
	• Types	ABC & CO ₂ type	provided	M.R.
	• IS marking	ISI marks	provided	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	Required	Provided	M.R.
	• Length of hose reel hose	30 m Required	Provided	M.R.
	• Nozzle diameter	5 mm Required	provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & heat	Provided	M.R.
	• Location of Main Panel	G. floor	Provided	M.R.
	• Location of Repeater Panel	Old case	Provided	M.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	Required	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	Provided	M.R.
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R.
	• Upper Floor	N.R.	N.R.	N.R.
	• Sprinkler above false ceiling	Required	Provided	M.R.

M-16

11.	Internal Hydrants			
	• Size of riser/down-comer	150 m	Provided	M.R. ✓
	• Number of hydrants per floor	1	Provided	M.R. ✓
	• Hose Box	1	Provided	M.R. ✓
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R. ✓
	• Hose Box	N.R.	N.R.	N.R. ✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R. ✓
	➤ Head of Main pump	N.R.	N.R.	N.R. ✓
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R. ✓
	➤ Pump Hose Access	N.R.	N.R.	N.R. ✓
	Terrace level			

11-19

	➤ Discharge of pump	2 x 450 LPM	Provided	M.R. ✓
	➤ Head of the pump	60 mtr	Provided	M.R. ✓
	➤ Power supply	Required	Provided	M.R. ✓
	➤ Auto Starting of pump	Required	Provided	M.R. ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.R	N.R	N.R. ✓
	➤ Fire service inlet	N.R	N.R	N.R
	➤ Access to tank	N.R	N.R	N.R
	➤ Overhead Tank Capacity	Old case	5,000 ltrs	M.R.
15	Exit Signage.	Required	Provided	M.R. ✓
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R	N.R	N.R
	• Pressurization of Lift lobby	N.R	N.R	N.R. ✓
	• Communication In lift Car	N.R	N.R	N.R
	• Fireman's Grounding Switch	N.R	N.R	N.R. ✓
	• Lift Signage	N.R	N.R	N.R
17.	Standby power supply	required	provided	M.R. ✓
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R. ✓

N-18

	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	required	provided	M.R. ✓
	➤ Flow Switch Panel	required	provided	M.R. ✓
	➤ PA system Panel	required	provided	M.R.
	➤ Batter backuplk	required	provided	M.R.
	➤ Building Floor plans	required	provided	M.R. ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R. ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O.

Designation