

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Ph - 23414333 Fax - 23412593 Email - cfohq.dlfire@nic.in

No. F6/DFS/MS/School/2013/ 414

Dated: 04/06/13

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Pratibha Vikas Vidyalaya, Gandhi Nagar, Delhi-31, comprised of ground plus two upper floors owned/occupied by Rajkiya Pratibha Vikas Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on dated 30.05.13 in the presence of Mr. Garib Dass, (HOS) of the school and that the building is fit for occupancy class B 'Educational Building' with effect from ...04/06/13... for a period of three years, subject to conditions printed overleaf.

Issued on.....04/06/13.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Delhi Fire Service

OK
Rsd
3/6/13

To,

The Principal,

Rajkiya Pratibha Vikas Vidyalaya, Gandhi Nagar, Delhi-31.

Copy to:-

The Joint Director of Education

(Land & Estate)

Directorate of Education, Lucknow Road, Delhi -54.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/10

INSPECTION REPORT

1. Name & address of the building : Rajkiya Pratibha Vikas Vidyalaya, Gandhi Nagar, Delhi-31.
2. Building is comprised of : G+2
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 30.05.13
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer from the building side : Mr. Garib Dass (HOS)
10. Year of Construction : 1960
11. Applicant's letter No : RPVV/GN/2013/199 dated 15.5.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	12 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 no.	02 no.	MR
	Upper Floor	02 no.	02 no.	MR
	Basement
	b. Width of Staircases	1.5 m	2 m, 1.26 m	MR
	Upper Floor	1.5 m	2 m, 1.26 m	MR
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR
g. Width of Corridor	1.5 m	2 m	MR	
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	Ventilated		
	Basement	30a/c per hour
	Upper floor	12 a/c per hour

5.	Fire Extinguisher	Required	Provided	
	Total numbers	16 no.	16 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA
9	Public address System.	Yes
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	Required	Provided	
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump
	➤ Head of the Pump	450 LPM	450 LPM	MR
	➤ Power supply	40 m	40 m	MR
	➤ Auto Starting of pump
	

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name

Suresh Singh

Designation

AD O

