

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2013/ *school/ 424*

Dated: *07/06/2013*

FIRE SAFETY CERTIFICATE

Certified that the – **Adarsh School, 3/12, West Patel Nagar, New Delhi-110008**
Comprised of - ground floor only, owned/occupied by the management has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 17.05.13 in the presence of Sh. S.K. Gupta, and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on*07/06/13*.....at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal,
Adarsh School,
3/12, West Patel Nagar,
New Delhi-110008.
2. The Director of Education
South Delhi Municipal Corporation
23rd floor, Dr. SPM Civic Centre,
Minto Road Gate,
New Delhi-110002.

1012

07

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Adarsh School, 3/12 West Gate Nagpur
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: —
5. Fire Safety directives letter No : NIL
6. Date of inspection : 17/05/13
7. Name of the Inspecting Officers : Div Officer H.L. ANEJA
8. Name and designation of officers from the building side : Sh. S.K. Gupta
9. Year of Construction : —
10. Applicant's letter No. : NIL dt 8/4/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	12 mtrs	MR
	• Gate width	R	1.50 mtrs	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NR	—	—
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	b. Width of staircases	NR	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	NR	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	R	100 cms	MR

3	Compartmentation.				
	• Fire check door	NR			
	• Sealing of electrical shafts				
	• Fire Rating of shaft door				
	• Water Curtain				
	• Fire Dampers				
4	Smoke Management System.				
	• Basements	NR			
	• Upper floors	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	• Total numbers	R	P	MR	
	• Types		3 Nos	-u-	
	• IS marking		ISI marked	-u-	
6	First-Aid Hose Reels.				
	• Total numbers on each floor	NR			
	• Length of hose reel hose	30 m			
	• Nozzle diameter	5 mm			
7	Automatic fire detection and alarming system.				
	• Type of detectors	NR			
	• Location of Main Panel				
	• Location of Repeater Panel				
	• Alternate source of power				
	• Hooters' Location				
8	MOEFA				
9	Public Address System.	NR			
10	Automatic Sprinkler System.				
	• Basement				


	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—	•
11	Internal Hydrants	NR	—	—	—
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—	—
12	Yard Hydrants.	NR	—	—	—
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—	—
13	Pumping Arrangements.	NR	—	—	—
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—	—
14	Captive Water Storage for fire fighting.	NR	—	—	—
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—	—

1	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 				
15	Exit Signage.				
16	Provision of Lifts.	NR			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR			
17	Standby power supply				
18	Refuge Area.	NR			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NR			
19	Fire Control Room	NR			
	<ul style="list-style-type: none"> • Detector System Panel • Fldw Switch Panel • PA System Panel • Batter backup • Building Floor Plans 				
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIC

5



Signature of the Inspecting Officer

Name H. L. ANEJA

Designation Dir. Officer

Signature of the Inspecting Officer

Name

Designation

