

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 011-23412593 E-mail : cfohq.dlfire@nic.in Ph. 011-23414333.


No.F6/MS/DFS/EH/2013/ 420

Dated :-----05/06/13-----

FIRE SAFETY CERTIFICATE

Certified that the M/s Blue Frog Restaurant (Unit of Blue Frog Media Pvt. Ltd.) located at 4-A, Kalkadas Marg, The Kila Complex, Mehrauli, New Delhi-110030, comprised of Ground Floor only was granted FSC by this department vide letter No.F6/DFS/MS/EH/2011/01 dated 02/01/12. The premises was re-inspected by the officer concerned of this department on 01/05/13 in the presence of Mr. Thareja & observed that the owner has added 45 more seats in operational area & the total seating capacity is now 225 and that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D Assembly Building with effect from-----5/6/13-----for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued -----5/6/13-----at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Dy. Health Officer,
MCD, South Zone, Green Park, New Delhi.

(2) Ms Blue Frog Restaurant (Unit of Blue Frog Media Pvt. Ltd.),
The Kila, 4-A, Kalkadas Marg, Mehrauli, New Delhi-110030.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Ms Blue Frog Restaurant (Unit of Blue Frog Media Pvt. Ltd.)The Kila,4-A,Kalkadas Marg,Mehrauli,New Delhi-110030.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal with addition of seats.
4. Details of previous NOC:-No. F6/DFS/MS/EH/2011/01 dated 02/01/12.
5. Fire safety directives No.- No
6. Date of inspection:-01/05/13
7. Name of the inspecting officer:-D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Threja.
9. Year of construction:- 2002.
10. Applicant's letter No:-DHO/SZ/2013/D/2134 dated 05/03/13 Ground floor only (added more operational area total seating capacity 225)

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	Provided	MR
	2) Gate width	2 mtr.	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr.	5 Nos. provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers		15 Nos.	MR

		ISI Marked	ABC, Co2 & W.Co2	MR
	2) Types		Yes	MR
	3) ISI marking			
6.	First-Aid Hose Reel		Provided	MR
	1) Total number of each floor	2 Nos.	Yes	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm		
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	NR	Provided (smoke & heat)	MR
	2) Location of main panel	NR	Provided in kitchen	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	NR	Battery backup	MR
	5) Hooter's Location	NR	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Yes	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	Provided	MR
	2) Number of hydrants per floor	2 Nos.	Provided	MR
	3) Hose box	2 Nos.	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	450 LPM	450 LPM	MR
	b) Head of main pump	40 mtr.	40 mtr.	MR
	c) Number of main pump	one	Provided	MR
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided (both)	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	10,000 ltrs.	Provided 20,000 ltrs.	MR
	a) Draw-off connection	N/A	N/A	N/A

	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- Dharampal Bharadwaj

Name:- S.S. Kaushik. 16/5/13

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer.