

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2013/445

Dated: 14/06/2013

FIRE SAFETY CERTIFICATE

Certified that the Jesus Mary Joseph School (name of the building or premises) located G-17, Paschim Vihar, New Delhi - 110088 and comprised of Ground + two upper floors occupied by Jesus Mary Joseph School was issued NOC vide this office letter no. F.6/DFS/MS/10/136 dated 13/1/10. The premises was re-inspected by the officer concerned of this department on 28/03/2013 in the presence of Mr. Mathew and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular dated 01/03/2011 and the building/ premises is fit for occupancy Educational with effect from 14/06/2013 for a period of three years subject to conditions printed below.

Issued on 14/06/13 at New Delhi.



Santokh Singh
Chief Fire Officer
Delhi Fire Service

E-mail : cfowz.dfire@nic.in

Phone : 011-23414250

Copy to:

1. The Principal, Jesus Mary Joseph School, G-17, Paschim Vihar, New Delhi.-110063
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

- Mr

INSPECTION REPORT

1. Name & address of the building : Jesus Mary Joseph School, G-17, P. Withan
2. Type of Occupancy : Educational (Ground + two upper floors)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.6/DPS/MS/10/136 Dated: 13/1/2010
5. Fire Safety directives letter No : —
6. Date of inspection : 28/3/2013
7. Name of the Inspecting Officers : ADO S.K. Dua
8. Name and designation of officers from the building side : Mr. Matthew
9. Year of Construction : 2009
10. Applicant's letter No. : JMS/NOC- 1 /2013 Dated 12/1/13
Recd. on 18/01/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	6.5 mtr.	Provided	MR
	• Width of internal road	NR	NA	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old case	1.34, 1.39, 1.38 mtr.	MR (old case)
	• Basements	NA	1.38 and 1.41 mtr.	NA
	c. Protection of exits			
	• Fire check door	NR	NP	—
	• Pressurization	NR	NP	—
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	1.5 mtr.	2.5 mtr.	MR
	h. Door Size	1.0 mtr.	1.2 mtr.	MR

< M/S -

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA open to sky	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	22 ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 30 m 5 mm	04 Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NR	NA	NA
9	Public Address System.	NR	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR

M/S

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/R	
17	Standby power supply	Required	Provided DG-125KVA	M/R
18	Refuge Area.			
	➤ Total Area		N/R	
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/R	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NO	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

S.K. Dua
2013

Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Signature of the Inspecting Officer

Name

Designation