

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Ph - 23414333 Fax - 23412593 Email - cfohq.dfire@nic.in

No. F6/DFS/MS/School/2013/ 442

Dated: 14/06/13

FIRE SAFETY CERTIFICATE

Certified that the E.D.M.C. Primary School, East Rohtash Nagar, Shahdara, Delhi-32, comprised of ground plus one upper floors owned/occupied by E.D.M.C. Primary School, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 30.05.13 in the presence of Principal of the school and that the building is fit for occupancy class 'B' Educational Building with effect from 14/06/13... for a period of **three** years, subject to conditions printed overleaf.

Issued on 14/06/13 at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

To,

The Principal (1st Shift)
E.D.M.C. Primary School, East Rohtash Nagar, Shahdara, Delhi-32

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.
2. The Principal (2nd Shift)
E.D.M.C. Primary School, East Rohtash Nagar, Shahdara, Delhi-32

076
12/6/13

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Nagar Nigam Prathmic Vidyalaya, 1st Shift, East Rohtash Nagar, Shahdara, Delhi-32
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- ----- Dated -----
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dt. 01.03.11
6. Date of Inspection : 31.07.12
7. Name of the Inspecting Officers : ADO Suresh singh
8. Name of the designation of Officer
From the building side : Mrs. Anita Sharma, Principal
9. Year of Construction : 2011
10. Applicant's letter No : dated 13.07.12

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	4 m	NMR /
	Gate width	Accepted as
	Width of internal road	one length of hose distance
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	MR
	Upper Floor
	Basement
	B. Width of Staircases	1.5 m	1.4 m each	MR
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	D. Pressurization
	e. No. of continuous staircases to terrace
	g. Width of Corridor	1.5 m	2.1 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	N/A		
	Basement	30a/c per hour
	Upper floor	12 a/c per hour
5.	Fire Extinguisher	Required		
	Total numbers	04 no.	04 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	ISI marked	ISI marked	MR

PRN-4

6	First-aid-Hose Reels.	N/A		
	Total numbers of each floor
	Length of hose reel hose	30 m
	Nozzle diameter	5 mm
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes
9	Public address System.	Yes
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	N/A		
	Ground Level
	Discharge of main Pump
	Head of Main Pump
	Number of main pumps
	Jockey pump out put
	Jockey pump head
	Standby pump out put
	Standby pump Head
	Auto Starting /Manual stopping
	Pump House Access
	Terrace Level
	Discharge of pump
	Head of the Pump
	Power supply
	Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity

15	Exit Signage.	N/A
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to issue shortcomings as noted at serial numbers 1

Signature of the Inspecting Officer
 Name Suresh Singh
 Designation ADD

Submitted for approval please.
& signatures