

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfohq.dlfire@nic.in

No *FG/DAS/ms/2013/439*

Dated *13/6/2013*

FIRE SAFETY CERTIFICATE

Certified that the Nalanda Cambridge School, Mandawali, Delhi. comprises of ground & two upper floors with 23 rooms have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 05 -06 – 2013 in the presence of Mr. Vivek I/c School. and that the premises is fit for occupancy of "Educational Building" with effect from *13-6-* 2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on *13/6/2013* at New Delhi.

[Handwritten Signature]
12/6

(DR.G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. 23414333

Copy to:-

1. The Principal
Nalanda Cambridge School,
Mandawali, Delhi.
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054

o/c
[Handwritten Signature]
12/6/13

Condition .

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

- 1. Name & address of the building: Nalanda Cambridge School,
Mandawali, Delhi.
- 2. Building is comprised of : Ground & two floors
- 3. Type of Occupancy : Educational.
- 4. Type of Case : New Case
- 5. Details of Previous NOC letter: NA
- 6. Fire Safety direction letter No : NA
- 7. Date of Inspection : 05-06-2013
- 8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
- 9. Name and designation of Officer: Principal
from the building side
- 10. Year of Construction : 1972
- 11. Applicant's letter No : F6/MS/DFS/08/2134 dated 20-05-
2013

S.N. O.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement.	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	20ft	30 ft	MR
	• Gate width
	• Width of internal road	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2Nos.	4Nos.	MR
	• Basement	NA	NA	NA
	B. Width of Staircases
	• Upper Floor	4N	1.5Mtr, .80Mtr, .75& 1.5Mtr	MR
	• Basement
	c. Protection of exits	-----	-----
	• Fire check door	NA	NA	NA
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	01	1No.	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1.0Mtr	1.0mtr	MR

-N/A-

3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper floor 	-----	-----	-----
		-----	-----	-----
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	4 Nos.	4 Nos.	MR
		ABC&CO2	ABC& CO2	MR
		Required	Provided	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers at ground floor • Length of hose reel hose • Nozzle diameter 	1No each floor	1No each floor	MR
		30Mtr.	30Mtr.	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power
	
		-----	-----	-----
		NA	NA	NA
	Hooter's location	-----	-----	-----
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • upper floor • sprinkler above false ceiling 	NA	NA	NA
		-----	-----	-----
		-----	-----	-----
11	Internal Hydrants	NA	Provided at Ground floor	MR
	<ul style="list-style-type: none"> • size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	100mm	MR
		NA	1No at Ground floor only.	MR
		1No	1No	MR
12	Yard Hydrants.	NA	NA	NA
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box
	
13	Pumping Arrangements.			

	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump.	450LPM	450LPM	MR
	➤ Head of the Pump	40Mtr	40 Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	10,000Ltr.	10,000Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	NA	NA	NA
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----

N/6-

	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Gurpreet Singh
5/6/13

Name GURPREET SINGH

Designation ADO (LN)

Dd(E)

CFO

[Signature]
5/6

Submitted for approval please.

[Signature]
5/6/13