

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.**

No. F6/DFS/MS/School/2013/444

Dated: 14/06/13

**FIRE SAFETY CERTIFICATE**

Certified that The Shri Krishna Public School (Name of building/premises) located at D-55, Chanchal Park, Nangloi-Najafgarh Road, Nangloi, New Delhi-41 comprised of ground floor with 10 class rooms owned and occupied by Shri Krishna Public School, have complied with the fire Prevention and fire safety requirements in accordance with circular issued by Directorate of Education, Govt. of NCT vide letter no. F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and verified by the officer concerned of fire service on 17-05-13 in the presence of Sh. Rajender Kumar Sharma (Manager) and the building/premises is fit for occupancy Educational (Group B) with effect from.....14/06/13..... for a period of 3 (three) years subject to conditions printed below.

Issued on.....14/06/13..... at New Delhi by.

13/6  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service  
Tel:-011-23414250  
Email:-cfowz.dlfire@nic.in

Copy to:-

1. The Manager, Shri Krishna public School, D-55, Chanchal Park, Nangloi-Najafgarh Road, Nangloi, New delhi-41.
2. The Director of Edu. , Govt. of NCT of Delhi, Old secretariat, Delhi.

**Following fire safety directives must be adhered to**

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authority.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

G.F. only , PA = 300 yard  
CA = 200 yard

1. Name & address of the building : Shri Krishna Public School  
D-55, Chanchal Park, Nangloi, Delhi-41
  2. Type of Occupancy : Educational (Ground only) 10 class rooms.
  3. Type of Case : New
  4. Details of previous NOC : —
  5. Fire Safety directives letter No. : DOE circular dated 1/3/2011
  6. Date of inspection : 17/5/2013
  7. Name of the Inspecting Officers : Ashok Kumar Jaiswal
  8. Name and designation of officers : Rajender Kumar Sharma (Manager)
- From the building side
9. Year of Construction : 2008
  10. Applicant's letter No. : Nil dated 3/5/2013

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	<del>BBL</del> Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	DOE circular Dated 1.3.11		
	• Road width	Required	Accessible	M/R
	• Gate width	Required	Provided	M/R
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NR	NR	NR
	• Upper Floors	NA	NA	NA
	• Basement	NA	NA	NA
	b. Width of staircases	_____		
		_____		



	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>			
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>			
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>			
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Provided	M/R
	f. Door size	Required 1.00 Mts.	Provided 1.60 Mts.	M/R
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>			
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>			
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>			
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>			
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>			
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>			
	<ul style="list-style-type: none"> <li>• Upper floor</li> </ul>			
5.	<b>Fire Extinguishers</b>			
	• Total numbers	2 CO2	Provided	M/R
	• Types	2 ABC	Provided	M/R
	• IS marking	ISI marks		
6.	<b>First-Aid Hose Rees.</b>			





7/11

	<ul style="list-style-type: none"><li>• Hose Box</li></ul>	NR	
--	--	----	--

**13. Pumping Arrangements.**

<b>Ground Level</b> <ul style="list-style-type: none"><li>➤ Discharge of main pump</li><li>➤ Head of Main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey Pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby pump out put</li><li>➤ Standby pump Head</li><li>➤ Auto Starting/Manual stopping</li><li>➤ Pump Hose Access</li></ul> <b>Terrace level</b> <ul style="list-style-type: none"><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power supply</li><li>➤ Auto Starting of pump</li></ul>			

**14. Captive Water Storage for fire fighting.**

<b>Underground tank capacity</b> <ul style="list-style-type: none"><li>➤ Draw -off connection</li><li>➤ Fire service inlet</li><li>➤ Access to tank</li></ul>			

	➤ Overhead Tank Capacity	NR		
15.	Exit Signage.			
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	NR		
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17.	Standby power supply			
18.	Refuge Area			
	➤ Total Area	NR		
	➤ Location			
19.	Fire Control Room			
	➤ Detector System Panel	NR		
	➤ Flow Switch Panel			
	➤ PA system Panel			
	➤ Batter backup			
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR		



The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial number~~.....

Ak Jaiswal  
17/5/2013

Signature of the Inspection Officer

Signature of the Inspection Officer

Name (ASHOK KUMAR JAISWAL)

Name

Designation Asst. Dir. officer

Designation