

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No F 6 / DFS / MS / GH / 2013 / 439


DATED 13/6/2013

FIRE SAFETY CERTIFICATE

Certified that the Oakland located at (A Unit of Green Valley Hospitality Pvt Ltd), CC - 27, Kalkaji, Nehru Enclave, New Delhi comprised of Basement, Ground + 3 Upper Floors Guest House is running at 1<sup>ST</sup> Floor to 3<sup>RD</sup> Floor having 27 guest room was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2010 / 501 dated 19.02.2010 in the name of Green Valley guest house. The premises was re-inspected by the officer concerned of this department on 05.06.2013 in the presence of Sh Bhupinder Singh and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy Class Lodging or Rooming House of Group - A with effect from ~~13/6/2013~~ for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to condition printed below.

Issued on ..13/6/2013..... at New Delhi

  
SANTOKH SINGH  
Chief Fire Officer  
Delhi Fire Service  
email ID : - cfowz.dfire.nic.in  
Ph - 011-23414250

  
13/6/13

Copy to:-

1. The Addl Commissioner of Police (lic)  
Police Station, Defence Colony, New Delhi
2. Oakland,  
(A Unit of Green Valley Hospitality Pvt Ltd),  
CC - 27, Kalkaji, Nehru Enclave, New Delhi

The following fire safety directives must be adhered to.

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This Fire Safety Certificate may not be treated in any case for regularization of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in Form K provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



### INSPECTION REPORT

1. Name & address of the building:- Oakland ,(A Unit of Green Valley Hospitality Pvt. Ltd.),CC – 27,Kalkaji,Nehru Enclave,New Delhi .
2. Type of occupancy:- Residential Lodging or Rooming Houses.
3. Type of case:- Renewal
4. Details of previous NOC:-F6/DFS/MS/GH/2010/501 dated 19/02/10
5. Fire safety directives No.- No
6. Date of inspection:- 05/06/2013
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Sh.Bhupinder Singh
9. Year of construction:- Not Known
10. Applicant's letter No:- 19004-06/Addl.C.P./Lic.(H) dated 25/04/13 comprised of Basement ,Ground + 3 Upper Floor having 27 guest room (Basement & Ground floor is others occupancy) G. House is running at 1<sup>st</sup> floor to 3<sup>rd</sup> floor.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Old Case Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	1 Nos.	Provided	MR
	2. Basements	1 Nos.	Provided	MR
	<b>B. Width of staircase</b>			
	1. Upper floors	Required	1.25 mtr.	MR Old case
	2. Basements	Required	1.25 mtr.	MR Old case
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	One	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	12 Nos.	MR
	2) Types		ABC & W.Co2	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			

*(Handwritten Signature)*



	1) Total number of each floor	One	1 at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/R	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Yes	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Yes	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/R	1Nos.Provided	MR
	2) Number of hydrants per floor	N/R	1Nos.Provided	MR
	3) Hose box	N/R	1Nos.Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Yes	Provided	MR
	d) Auto starting of pump	Yes	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/R	20,000 ltrs.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Yes	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Yes	Provided	MR

*M. S. S. S.*

	e) Lift signage	Yes	Provided	MR
17.	<b>Stand by Power Supply</b>	Yes	D.G. Set	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The shortcomings communicated vide letter dated 04/01/13 found complied.

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up please

Signature of the inspecting officer

Signature of the inspecting officer

Name :-

Name:- S.S.Kaushik.

Designation:-

Designation:- Assistant Divisional Officer.

~~Desai~~

W  
10/6/13

*S.S. Kaushik*  
7/6/13