

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/W2/467
FIRE SAFETY CERTIFICATE

Dated: 21/06/2013

Certified that the Dayawati Public School is comprised of Ground & One upper Floor with 07 Class Rooms located at C-Block, Mukandpur, Delhi-110042, owned / occupied by Sisodia Educational society complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 27/05/2013 in the presence of Mrs. Parshu Ram and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 21/06/2013 for a period of three years, subject to compliance of the conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 21/06/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dfire@nic.in

Copy to:

1. The Principal, Dayawati Public School, C-Block, Mukandpur, Delhi-110042.
2. The Addl. Director of Education, NMCD, Civic Centre, New Delhi.



21

INSPECTION REPORT

1. Name & address of the building: Dayawati Public School, C-Block, Gali No. 10,
2. Type of Occupancy: Educational
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. Nil Dated: _____
5. Fire Safety directives letter No: Circular, Dir. of edun. 1/3/2011
6. Date of inspection: 27-5-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Sh. Parshu Ram
9. Year of Construction: 2003 (Ground + one)
10. Applicant's letter No.: 16/DWPS/2013-14 dt. 22-4-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	Accessible	5 m MIR
	• Gate width	-u-	5.45 m MIR
	• Width of internal road	-u-	open ground open ground.
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	1	1 MIR
	• Upper Floors	1	1 MIR
	• Basements	Nil	Nil
	b. Width of staircases		
	• Upper Floors	1.5 m	1.5 m MIR
	• Basements	Nil	Nil
	c. Protection of exits		
	• Fire check door		NIR
	• Pressurization		1
	e. No. of continuous staircases to terrace		
	g. Width of Corridor	R	2.5 m MIR
	h. Door Size	1 m	1 m (Double door) MIR
3	Compartmentation.		
	• Fire check door		NIR
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	NIR
	• Upper floors	12 a/c per hour	1

N/R

M

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>OU ABC/CO2(2.5kg) ISI marked</p>	<p>Provided</p> <p>Provided</p> <p>Provided</p>	<p>M/R</p> <p>M/R</p> <p>M/R</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m</p> <p>5 mm</p>	<p>N/R</p> <p>/</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		<p>N/R</p> <p>/</p>	
8	MOEFA			
9	Public Address System.		<p>N/R</p> <p>N/R</p>	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		<p>N/R</p> <p>/</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		<p>N/R</p> <p>/</p>	
12	Yard Hydrants..			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		<p>N/R</p> <p>/</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		<p>N/R</p> <p>/</p>	

Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NIR
15	Exit Signage.		NIR
16	Provision of Lifts.		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A
17	Standby power supply		NIR
18	Refuge Area.		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A
19	Fire Control Room		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		NIR
20	Special Fire Protection Systems for Protection of special Risks, if any:		NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer 27/5/2013

Name

DO. (NW)

Name

(SHYAM LAL)

Designation

Officer

Designation

Assist. Divn. Officer