

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax : 23412593, E-mail: cfhq. dlfire@nic.in Tel :- 011-23414333

No. F6/MS/DFS/Cinema/2013/ *N02/466*

Dated: *21/06/13*

FIRE SAFETY CERTIFICATE

Certified that M/s **Imperial Cinema** located at Raj Guru Road, Chunna Mandi, Pahar Ganj, New Delhi-110055 comprised of ground floor plus one upper floor owned / occupied by Imperial Cinema complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 28-05-13 in presence of Shri Omparkash Manager and that the building / premises is fit for occupancy **Assembly Class 'D'** building with effect from **28-05-13** for a period of one year in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued *21/06/13* at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w. r. t. letter No.5706-10 Addl.C.P./Lic.(H) New Delhi dated 06-02-13.
2. M/s **Imperial Cinema** located at Raj Guru Road, Chunna Mandi, Pahar Ganj, New Delhi-110055.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: IMPERIAL CINEMA Raj Gura Road, Chuna Mandi Paharganj
2. Type of Occupancy: Assembly C Cinema hall
3. Type of Case: Re-newal
4. Details of previous NOC: Letter No F6/DFJ/MS/CINEMA/2012/3484
5. Fire Safety directives Letter No.: DT-24/9/13
6. Date of inspection: 28/5/2013
7. Name of the Inspecting Officer: ADD Manoj K. Sharma
8. Name and designation of Officer from the building side: Sh. Mukesh Gaur IE(C) MCD.
9. Year of Construction: 1956 and Structural Safety reviewed in 2003
10. Applicant's letter No.: IC/2013 DT 13/5/13


S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width <u>16 Mts.</u>	<u>Directly accessible from two side</u>		<u>from Main Road MIR</u>
	• Gate width	<u>On Road</u>		<u>MIR.</u>
	• Width of internal road	<u>N.A.</u>	<u>N.A.</u>	<u>NA.</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	<u>02</u>	<u>02</u>	<u>-</u>
	• Upper floors <u>1.8 Ml } 1.4 Ml } 0.8 Ml }</u>	<u>02.</u>	<u>2 up to 1st flr 1 up to Terrace</u>	<u>MIR.</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors			
	• Basements			
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>MIR</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>MIR</u>
	d. No of continuous staircase to terrace	<u>01</u>	<u>01</u>	<u>MIR</u>
	e. Width Of Corridor	<u>NA</u>	<u>NA</u>	<u>MIR</u>
	f. Door Size	<u>1.5 Ml</u>	<u>1.5 Ml</u>	<u>MIR</u>

3.	Compartmentation			
	* Fire check door	N A.	N A	MIR
	* Sealing of electrical shafts			
	* Fire Rating of shaft door			
	* Water Curtain	N A	N A	MIR
	* Fire Dampers	N A	N A	MIR
4.	Smoke managements System			
	* Basements	30 a/c per hour	N A	MIR
	* Upper floors	12 a/c per hour	EXHAUST FAN provided	MIR
5.	Fire Extinguishers 23			
	* Total numbers			
	* Types ABC, CO ₂ , water etc.			
	* IS marking	(SI marked)		
6.	First - Aid Hose Reels 03			
	* Total numbers on each floor	G-flr - 2 I st flr - 01.	02 01.	MIR
	* Length of hose reel hose	30 Mb	30 Mb	MIR
	* Nozzle diameter	6 mm.	6 Mb	MIR
7.	Automatic fire detection and alarming system			
	* Type of detectors	N A	N A	MIR.
	* Location of Main Panel		I st flwr	
	* Location of Repeater Panel			
	* Alternate source of power		40 KVA	
	* Hooters' Location		N.A.	
8.	MOEFA	N A	N A	MIR
9.	Public Address System	Provided	Provided	MIR
10.	Automatic Sprinkler System			
	* Basements	N A	N A	MIR
	* Upper Floor			

11.	* Sprinkler above false ceiling	NA	NA	MIR
	Internal Hydrants			
	* Size of riser/down-comer	NA	NA	MIR
	* Number of hydrants per floor	NA	NA	MIR
	* Hose Box	NA	NA	MIR
12.	Yard Hydrants	NA	NA	
	* Total number of hydrants	NA		
	* Hose Box	NA		
13.	Pumping Arrangements			
	* Ground Level			
	* Discharge of main pump	220 Lpm	220 Lpm	MIR
	➤ Head of main pump	30 m	30 m	MIR
	➤ Number of main pumps	ONE	ONE	MIR.
	➤ Jockey pump out put	-	-	-
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access	G-Flow	G-Flow	MIR
	* Terrace level	Shed.		
	➤ Discharge of pump	17 m	17 m	MIR
	➤ Head of the pump	NA	NA	MIR
	➤ Power supply	NA	NA	MIR
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	* Under ground tank capacity	NA	NA	MIR
	➤ Draw of connection	NA	NA	MIR
	➤ Fire service inlet	NA	NA	MIR
	➤ Access to tank	Provided	Provided	MIR
	* Overhead Tank capacity	10,000 lit	10,000 lit	MIR
15.	Exit Signage	Provided	Provided	MIR

Important

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	MIR
	➤ Pressurization of lift lobby	NA	NA	MIR
	➤ Communication in lift Car	NA	NA	MIR
	➤ Fireman's Grounding Switch	NA	NA	MIR
	➤ Lift Signage	NA	NA	MIR
17.	Standby power supply	DG set	Provided	MIR
18.	Refuge Area	NA	NA	MIR
	➤ Total area		/	
	➤ Location		/	
19.	Fire control room	NA		
	➤ Detector system panel	NA	NA	
	➤ Flow Switch Panel	NA	NA	
	➤ PA System Panel	Provided	Provided	MIR
	➤ Batter backup	NA	NA	MIR
	➤ Building Floor Plans	OK	OK	MIR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Provided	Provided	MIR



The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Do (CD)

Signature of the Inspecting Officer

Name

Designation

Manshu
20/6/13

Signature of the Inspecting Officer

Name

Manshu K. Shrivastava

Designation

Asst. Dir. of B.

Submitted please
17-6-13