

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI
(E-mail id: cfhq.dlfire@nic.in)(011-23414333)

No F 6 / DFS / MS / 2013 / EH / 52 / 486

Dated 26/06/13

FIRE SAFETY CERTIFICATE

Certified that the "Pind Balluchi" Restaurant situated at Mezzanine & First floor (Mezzanine floor is used for office, first floor used for restaurant) located at 17, Community Centre, Saket, New Delhi 110016 was granted NOC by this department vide letter No F6/ MS / DFS / EH / 2009 / 3270 dated 06.11.2009 in the name of Buzz Restaurant. The premises was re-inspected by the officer concerned of this department on 17.06.2013 in the presence of Mr. Dheeraj (Manager) and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from 26/06/13... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/06/13..... at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Assistant Commissioner of Police, (Lic), 1st floor, PS Defence Colony, New Delhi
2. Mr. Manohar Lal Grover, (Director) Pind Balluchi, Restaurant at First Floor, 17, Community Centre, Saket, New Delhi - 110016.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Pind Balluchi Restaurant, 17, Commercial Centre,
Saket, New Delhi - 110016
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/MS/DFS/EH/2009/3270 Dated 06.11.2009
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 17.06.2013
7. Name of the Inspecting Officer : Dy. CFO Atul Garg
8. Name and designation of Officer
from the building side : Mr. Dheeraj
9. Year of Construction : N/A
10. Applicant's letter No. : Nil Dated 01.05.2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	12 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.10 mtr	1.10 mtr	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	02 of 1mtr each	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	YES	MR(exhaust fan provided)
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 		10	MR
			CO ₂ , DCP	MR
			YES	MR
		ISI marked		
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	-	01	MR
		30 m	YES	MR
		5 mm	YES	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	YES	YES	MR
9.	Public Address System	YES	YES	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		YES	YES	MR
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	100 mm	YES	MR
		01	YES	MR
		01	YES	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 Lpm 180 Lpm	YES	MR
		30 M	30 M	MR
		YES	YES	MR
		YES	YES	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5000 L	5000 L	MR
15.	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- One internal staircase having width of .75 mtr connected 1st floor and mezzanine is also available.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation



ATUL GARG

DLFO

