

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001
Fax:23412593,E-mail:cfohq.dlfie@nic.in

No. *FG/DFS/MS/EH/2013/ND2/470*

Dated: *24/06/13*

FIRE SAFETY CERTIFICATE

Certified that the True Blue Restaurant at First & Second floor of a building comprising of ground plus three upper floors at Atlantic Plaza, Plot No.4,L.S.C -II, I.P.Extn.,Delhi -92, owned/occupied by M/s Parish Enterprises Pvt.Ltd.,was granted NOC vide letter no. No.F.6/MS/DFS/EH/2009/1972 dated 06.07.2009 .The restaurant building was inspected by the officer concerned of this department on 10.06.13 in the presence of Sh.Naresh Saini (Manager) and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D "Assembly Building" with effect from *24/06/13* for a period of three years, subject to conditions printed overleaf.

Issued on *24/06/13* at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph.23414333

To,
Sh.Harminder Singh
True Blue Restaurant
M/s Parish Enterprises Pvt.Ltd.
Atlantic Plaza, Plot No.4,L.S.C -II,
I.P.Extn.,Delhi -92



CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: True Blue Restaurant at Atlantic Plaza, Plot No.4,
L.S.C-II, I.P. Extn, Delhi -92.
2. Building is comprised of : Ground + 3, upper floors.
3. Type of Occupancy : Restaurant (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/MS/DFS/EH/2009/1972 dated 06.07.2009.
6. Fire Safety direction letter No : F.6/MS/DFS/2005/718 dated 04.04.2005.
7. Date of Inspection : 10.06.13
8. Name of the Inspecting officers: DO Virendra Singh,
9. Name and designation of Officer:
from the building side : Sh.Naresh Saini (Manager)
10. Year of Construction - : 2002
11. Applicant's letter No : 21.05.2013

NO.	Minimum Standards on fire prevention and fire safety U/R33	(Old) Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	4.5 Mtrs.	15 Mtrs.	MR
		-----	-----	-----
		-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floor • Basement 	2 Nos.	1Nos. + 1 staircase through adjoining building (horizontal exit)	Acceptable as old case
	B. Width of Staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floor • Basement 	-----	1.20 & 1.10 Mtrs	Acceptable as old case
		-----	-----	-----
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-----	-----	-----
		-----	-----	-----
	e. No. of continuous staircases to terrace	-----	1No.	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1.0 Mtrs	1.0 & 1.10 Mtrs	Acceptable as old cas
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	-----	-----	-----

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	Required	Provided	MR
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	-----	-----	-----
		-----	-----	-----
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers types 	8 Nos. ABC & Co2	10 Nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1no.	1 no.	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		Required	Provided	MR
	<ul style="list-style-type: none"> Hooter's location 	-----	-----	-----
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor(1st & 2nd) sprinkler above false ceiling 	-----	-----	-----
		Required	Provided	MR
		-----	-----	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box 	100 MM	Provided	MR
		1 No.	Provided	MR
		1 No.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-----	-----	-----
		-----	-----	-----
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----

IRN-9

	➤ Jockey pump out put	225 LPM	225 LPM	MR
	➤ Jockey pump head	35 M	Provided	MR
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	35 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	-----	-----	-----
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



CSO
19/6

Signature of the Inspecting Officer
Name **VIRENDRA SINGH**
(DOLE)