

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

(E-mail id: cfohq.dlfire@nic.in) (011-23414333)


No F 6 / DFS / MS / 2013 / *School / S2/11496*

Dated *28/06/13*

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya at Ward No. 173, Saidulajab, New Delhi – 110030. Comprised of Ground plus one upper floor owned / occupied by Nigam Pratibha vidyalaya have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 17.05.2013 in the presence of Smt. Santosh Kumari Yadav, Principal of the school and that the building is fit for occupancy class Group 'B' Education Building with effect from *28/06/13* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *28.06.13* at New Delhi


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

To

1. Director of Education,
Government of NCT of Delhi.
2. Principal, Nigam Pratibha Vidyalaya,
Ward No. 173, Saidulajab, New Delhi.

Conditions:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Nigam Pratibha Vidyalaya, Ward No.173, Saidulajab, New Delhi
2. Building is comprised of : G +1
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : Circular Director of Education dtd. 01.03.11
7. Date of Inspection : 17.05.2013
8. Name of the Inspecting officers : ADO D.B.Mukherjee
9. Name and designation of Officer from the building side : Smt.Santosh Kumari Yadav (Principa.)
10. Year of Construction - : 2012
11. Applicant's letter No : Dated 26.04.2013

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	Provided	MR
	• Gate width		4.5m & 3.75m	MR
	• Width of internal road	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	-----	-----	-----
	B. Width of Staircases			
	• Upper Floor	1.5 M	Provided 2 M	MR
	• Basement	-----	-----	-----
	c. Protection of exits			
	• Fire check door	-----	-----	-----
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	-----	-----	-----
		1.5 mts.	Provided	MR

	g. Width of Corridor h. Door Size	1.0 Mtrs	Provided	MR
3	Compartmentation.			
	• Fire check door	-----	-----	-----
	• Sealing of electrical shafts	-----	-----	-----
	• Fire rating of shaft door	-----	-----	-----
	• Water curtain	-----	-----	-----
	• Fire Dampers	-----	-----	-----
4	Smoke Management System.			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5.	Fire Extinguishers			
	• Total numbers	7 Nos.	7 Nos.	MR
	• types	ABC & Co2	ABC	MR
	• IS marking	ISI marked	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	-----	-----	-----
	• Length of hose reel hose	-----	-----	-----
	• Nozzle diameter	-----	-----	-----
7	Automatic fire detection and alarming system.			
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	• Hooter's location	-----	-----	-----
8	MOEFA	-----	-----	-----
9	Public address System.	-----	-----	-----
10	Automatic Sprinkler System.			
	• Basement	-----	-----	-----
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants			
	• size of riser/down-comer	-----	-----	-----
	• Number of hydrants per floor	-----	-----	-----
	• Hose Box	-----	-----	-----
12	Yard Hydrants			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----

	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump	-----	-----	-----
	➤ Head of the Pump	-----	-----	-----
	➤ Power supply	-----	-----	-----
	➤ Auto Starting of pump	-----	-----	-----
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	-----	-----	-----
15	Exit Signage.	-----	-----	-----
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.			
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room			
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire extinguishers provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

DO (South)

Verify the details of staircase

27/5/13

Signature of the Inspecting Officer

Name D. B. Munkhija

Designation AAO (B&P)