

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.

F6/DFS/MS/EH/2013/W2/522

Dated: 08/07/2013

FIRE SAFETY CERTIFICATE

Certified that the **Mc Donald's Family Restaurant** by Connaught Plaza Restaurant Pvt. Ltd. located at DT City Centre, shop no. 2,3 & 4 on ground floor and storage at shop no. 102, on first floor, Block -A Community Centre, Shalimar Bagh, New Delhi of a premise comprised of lower basement, upper basement and five upper floors was issued NOC vide letter no.F6/DFS/MS/2009/297 dated 03/02/2009, owned/occupied by M/s **McDonalds Family Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **18-06-2013** in the presence of **Sh. D.N. Thakur** and that the building/premises is fit for occupancy **Class D (Assembly)** with effect from08/07/13.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Subject to condition printed below.

Issued on.....08/07/13.....at New Delhi by

CS

Santokh Singh
Chief Fire Officer
Delhi Fire Service
E-mail cfowz.dlfire@nic.in
Tel.: 011-23414250

dc 4

Copy to

1. **Sh. D.N. Thakur**

McDonalds Family Restaurant by Connaught Plaza Restaurant Pvt. Ltd at "DT City Centre", Shop no. 2, 3, & 4 on ground floor & Shop no. 102, on First floor, Block-A, Community Centre, Shalimar Bagh, New Delhi

2. DHO, Municipal Corporation of Delhi (Rohini Zone)

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 30-05-2013 received from the Authorized Signatory, regarding NOC in r/o McDonalds Family Restaurant by Connaught Plaza Restaurant Pvt. Ltd located at "DT City Centre", Shop no. 2,3, & 4 on ground floor & Shop no. 102, First floor, Block-A, Community Centre, Shalimar Bagh, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **McDonalds Family Restaurant** by Connaught Plaza Restaurant Pvt. Ltd located at "DT City Centre", Shop no. 2, 3, & 4 on ground floor & storage at Shop no. 102, on First floor, Block-A, Community Centre, Shalimar Bagh, New Delhi.
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 18-06-2013
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. D.N. Thakur
9. Year of Construction : 2007
10. Applicant's letter No. : nil dated 30-05-2013

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	For the Mall			
	• Road width	12 mtrs	24 mtr ✓	M/R
	• Gate width	4.5 mtr	5 mtr ✓	M/R
	• Width of internal road	6 mtr	Provided ✓	M/R
2.	Number, Width, Type & Arrangement of Exits			
	For the Mall			
	a. Number of staircases	10	Provided ✓	M.R.
	• Upper Floors	10	10 ✓	M.R
	• Basement	16	16 ✓	M.R
	b. Width of staircases			
	• Upper Floors	1.5 mtr & 2 mtr ✓	Provided	M.R.

	<ul style="list-style-type: none"> Basement 	1.5 mtr & 2 mtr	Provided	M.R.
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	M.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Provided	M.R.
	f. Door size	2 doors of 2 mtr each	Provided	M.R.
3.	Compartmentation. Of the Mall			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Water Curtain 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R.
4.	Smoke Management System. OF the Mall			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R.
5.	Fire Extinguishers For Restaurant			
	<ul style="list-style-type: none"> Total numbers 	04	06	M.R.
	<ul style="list-style-type: none"> Types 	ABC & CO ₂	provided	M.R.
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R.

7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	Smoke & Heat type	Provided	M.R
		Ground floor	Provided	M.R
		N.R.	N.R.	N.R.
		Required	Provided	M.R
		Required	Provided	M.R
18.	MOEFA	Required	Provided	M.R
9.	Public Address System.	N.R.	N.R.	N.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	M.R.
		Required	Provided	M.R
		Required	Provided	M.R
11.	Internal Hydrants Of the Mall			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150 mm	provided	M.R
		4	Provided	M.R
		4	Provided	M.R
12.	Yard Hydrants For the Mall			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	6	Provided	M.R
		6	Provided	M.R
13.	Pumping Arrangements. Of the Mall			
	Ground Level			
	<ul style="list-style-type: none"> ➤ Discharge of main pump ➤ Head of Main pump 	4500 LPM	Provided	M.R
		60 mtr	Provided	M.R

	➤ Number of main pumps	3 Pumps 1. Electrical pump =Wet riser 1. Electrical pump =Sprinkler 1. Diesel driven pump=Stand by	Provided	M.R
	➤ Jockey Pump out put	Two 180 LPM each	Provided	M.R
	➤ Jockey pump head	60 mtr	Provided	M.R
	➤ Standby pump out put	4500 LPM	Provided	M.R
	➤ Standby pump Hcad	60 mtr	Provided	M.R
	➤ Auto Starting/Manual stopping	Required	Provided	M.R
	➤ Pump Hose Access	Required	Provided	M.R
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R
	➤ Head of the pump	40 mtr.	Provided	M.R
	➤ Power supply	Provided	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for fire fighting. <i>for the mall.</i>			
	Underground tank capacity	3 lacs ltrs	Provided	M.R
	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	30, 000 ltrs	Provided	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts	For the Mall	For the Mall	
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R

	<ul style="list-style-type: none"> • Communication In lift Car 	Required	Provided	M.R
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	M.R
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	M.R
17.	Standby power supply	Required	450 KVA	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
19.	Fire Control Room	For the Mall	For the mall	For the mall
	➤ Detector System Panel	Required	Provided	M.R
	➤ Flow Switch Panel	Required	Provided	M.R
	➤ PA system Panel	Required	Provided	M.R
	➤ Battery backup	Required	Provided	M.R
	➤ Building Floor plans	Required	Provided	M.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chawdhary

Name

Designation (D.O.)

Designation