

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfhq.dfire@nic.in

No F6/DFS/MS/School/2013/ND2/507

Dated: 03/07/13

FIRE SAFETY CERTIFICATE

Certified that the Raghbir Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi - 110006 owned / occupied by Raghbir Saran Public School building comprised of ground floor have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01-03-2011 and verified by the officer concerned of Delhi Fire Service on 20-06-2013 in the presence of Sh. Manoj Kaushik Asst. Supervisor and that the building is fit for occupancy class B "Educational Building" with effect from 03/07/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions rule 38 of the Delhi Fire subject to the condition printed overleaf.

Issued on 03/07/12 at New Delhi by.



(Dr G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph - 011-23414333

Copy to:-

1. The Raghbir Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi - 110006
2. The Director Education, Old Secretariat, Delhi - 110054.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/2

Raghubir Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi-110006

**INSPECTION REPORT**

Name & address of the building : Raghubir Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi-110006

Type of Occupancy : Educational (School)

Type of Case : New Case

Details of previous NOC : Letter No. No. N/A dated

Fire Safety directives Letter No. : N/A

Date of inspection : 20-06-2013

Name of the Inspecting Officer : Sh. Manoj Sharma (A.D.O.)

Name and designation of Officer from the building side : Sh. Manoj Koshik (Asst. Supervisor)

Year of Construction : N/A

Applicant's letter No. : Nil Dated Nil

Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
<b>Access of building</b>			
• Road width	Accessible	Accessible from main road	MR
• Gate width	N/A	16 feet	N/A
• Width of internal road	N/A	N/A	N/A
<b>Number, width, Type &amp; Arrangements of exits</b>			
a. Number of staircases			
• Upper floors	N/A	N/A	N/A
• Basements	N/A	N/A	N/A
b. Width of staircases			
• Upper floors	N/A	N/A	N/A
• Basements	N/A	N/A	N/A
c. Protection of exits			
• Fire check door	N/A	N/A	N/A
• Pressurization	N/A	N/A	N/A
d. No of continuous staircase to terrace	N/A	N/A	N/A
e. Width Of Corridor	N/A	N/A	N/A
f. Door Size	N/A	N/A	N/A
<b>Compartmentation</b>			
• Fire check door	N/A	N/A	N/A
• Sealing of electrical shafts	N/A	N/A	N/A
• Fire Rating of shaft door	N/A	N/A	N/A
• Water Curtain	N/A	N/A	N/A
• Fire Dampers	N/A	N/A	N/A
<b>Smoke managements System</b>			
• Basements	30 a/c per hour	N/A	N/A
• Upper floors	12 a/c per hour	N/A	N/A

Sh  
H.B



M/3

Agarwal Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi-110006

<b>Fire Extinguishers</b>			
• Total numbers	05	05	MR
• Types	.....	Water Co2 & A.B.C. type.	MR
• IS marking	ISI marked	Provided	MR
<b>First – Aid Hose Reels</b>			
• Total numbers on each floor	N/A	N/A	N/A
• Length of hose reel hose	30 M	N/A	N/A
• Nozzle diameter	5 mm	N/A	N/A
<b>Automatic fire detection and alarming system</b>			
• Type of detectors	N/A	N/A	N/A
• Location of Main Panel	N/A	N/A	N/A
• Location of Repeater Panel	N/A	N/A	N/A
• Alternate source of power	N/A	N/A	N/A
• Hooters' Location	N/A	N/A	N/A
MOEFA/Siren	Required	provided	MR
Public Address System	Required	provided	MR
<b>Automatic Sprinkler System</b>			
• Basements	N/A	N/A	N/A
• Upper Floor	N/A	N/A	N/A
• Sprinkler above false ceiling	N/A	N/A	N/A
<b>Internal Hydrants</b>			
• Size of riser/down- comer	N/A	N/A	N/A
• Number of hydrants per floor	N/A	N/A	N/A
• Hose Box	N/A	N/A	N/A
<b>Yard Hydrants</b>			
• Total number of hydrants	N/A	N/A	N/A
• Hose Box	N/A	N/A	N/A
<b>Pumping Arrangements</b>			
• Ground Level			
• Discharge of main pump	N/A	N/A	N/A
➤ Head of main pump	N/A	N/A	N/A
➤ Number of main pumps	N/A	N/A	N/A
➤ Jockey pump out put	N/A	N/A	N/A
➤ Jockey pump head	N/A	N/A	N/A
➤ Standby Pump out put	N/A	N/A	N/A
➤ Standby Pump Head	N/A	N/A	N/A
➤ auto Starting/Manual stopping	N/A	N/A	N/A
➤ Pump House Access	N/A	N/A	N/A
• Terrace level			
➤ Discharge of pump	N/A	N/A	N/A
➤ Head of the pump	N/A	N/A	N/A
➤ Power supply	N/A	N/A	N/A
➤ Auto starting of pump	N/A	N/A	N/A
<b>Captive water Storage for fire fighting</b>			
• Under ground tank capacity	N/A	N/A	N/A
➤ Draw of connection	N/A	N/A	N/A
➤ Fire service inlet	N/A	N/A	N/A
➤ Access to tank	N/A	N/A	N/A
• Overhead Tank capacity	N/A	N/A	N/A
Exit Signage	Required	Provided	MR
<b>Provision of Lifts</b>			
➤ Pressurization of Lift Shaft	N/A	N/A	N/A

M/9

Shubir Saran Public School, 6631-32, Chamelian Road, Bara Hindu Rao, Delhi-110006

➤ Pressurization of lift lobby	N/A	N/A	N/A
➤ Communication in lift Car	N/A	N/A	N/A
➤ Fireman's Grounding Switch	N/A	N/A	N/A
➤ Lift Signage	N/A	N/A	N/A
Standby power supply	N/A	N/A	N/A
Refuge Area			
➤ Total area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
Fire control room			
➤ Detector system panel	N/A	N/A	N/A
➤ Flow Switch Panel	N/A	N/A	N/A
➤ PA System Panel	N/A	N/A	N/A
➤ Batter backup	N/A	N/A	N/A
➤ Building Floor Plans	N/A	N/A	N/A
Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules

De (C/D)

Signature of the Inspecting Officer

Name  
Designation

Menshu  
24/6/13

Signature of the Inspecting Officer

Name  
Designation

M K (CHARMA)  
Asst. In-charge Officer