

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FG/DFS/MS/BNCT/2013/W2/523

Dated: 08/07/2013

FIRE SAFETY CERTIFICATE

Certified that the **M/s Shubh Nimantran Banquet** located at 7/25 Kirti Nagar, Industrial Area, New Delhi, comprised of Basement+Ground+three upper floors, owned/occupied by **M/s Shubh Nimantran Banquet** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **14-06-2013** in the presence of **Mr. Amit & Parveen Gupta** of the Banquet Hall and that the building/premises is fit for occupancy **Class-D Assembly** with effect from08/07/13.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....08/07/13.....at New Delhi by

St,
(SANTOKH SINGH)

Chief Fire Officer
Delhi Fire Service

E-mail:cfowz.dlfire@nic.in

Tel No. 011- 23414250

Copy to:
The Director
M/s Shubh Nimantran Banquet
7/25 Kirti Nagar, Industrial Area, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on **www.dfs.delhigovt.nic.in**

N/13

1. Name & address of the building : Shubh Nimmastan, 7/25 Kirti Nagar 2nd M.D.
 2. Type of Occupancy : Assembly (B+G + ^{three in} two upper floors)
 3. Type of Case : NEW
 4. Details of previous NOC : Nil
 5. Fire Safety directives letter No. : FG/DFS/MS/BR/20/2/28/5 dt. 31/7/12
 6. Date of inspection : 14-06-2013
 7. Name of the Inspecting Officers : D.O. Sunil Chaudhary
 8. Name and designation of officers : Mr. Amit and Parveen Gupta
- From the building side
9. Year of Construction : 2009 ✓
 10. Applicant's letter No. : DHO/BSKZ/20/2/1182 dt. 13/5/13

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtr	25 mtr	MR dh
	• Gate width	5 mtr	Provided dh	MR dh
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2 Stair Case	Provided ✓	MR
	• Basement	1)	1)	1)
	b. Width of staircases			

dh

2/14

	<ul style="list-style-type: none"> Upper Floors 	1.5 mtrs. each	Provided	MR	
	<ul style="list-style-type: none"> Basement)) ✓	MR	
c.	Protection of exits				
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	MR	
	<ul style="list-style-type: none"> Pressurization 	Required	Provided ✓	MR	
d.	No. of continuous staircases to terrace				
e.	Width of Corridor	2 mtrs. ✓	Halls only	MR	
f.	Door size	2 doors of 2 mtrs width at each floor	Provided	MR	
3.	Compartmentation.				
	<ul style="list-style-type: none"> Fire check door 	Required ✓	Provided	MR	
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N.A.	N.A.	NA	
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA	
	<ul style="list-style-type: none"> Water Curtain 	NR	NR	NR	
	<ul style="list-style-type: none"> Fire Dampers 	Required ✓	Provided	MR	
4.	Smoke Management System.				
	<ul style="list-style-type: none"> Basements 	Required ✓	Provided	MR	
	<ul style="list-style-type: none"> Upper floor 	Required ✓	Provided	MR	
5.	Fire Extinguishers				
	Total numbers	Water 9Ltr. - 2	2 at each floor.	Provided	MR
	Types	CO2 4.5 Kg. DC type 5kg		Provided	MR
	IS marking	ISI marks	Provided	MR	
6.	First-Aid Hose Reels.				

dh

N/A

dh

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>two Required //</p> <p>30 m</p> <p>5 mm</p>	<p>Provided ✓</p> <p>//</p> <p>//</p>	<p>MR</p> <p>//</p> <p>//</p>
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	<p>Smoke/Heat</p> <p>GF</p> <p>At each floor</p> <p>Required</p> <p>Required</p>	<p>Provided & Functional ✓</p> <p>Provided ✓</p> <p>at each floor ✓</p> <p>Provided ✓</p> <p>Provided ✓</p>	<p>MR</p> <p>MR</p> <p>MR dh</p> <p>MR</p> <p>MR</p>
8.	MOEFA	Required	Provided ✓	MR
9.	Public Address System.	Required	Provided ✓	MR
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>Required</p> <p>Required</p> <p>N/A</p>	<p>Provided ✓</p> <p>Provided ✓</p> <p>N/A</p>	<p>MR</p> <p>MR</p> <p>N/A</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>150 mm</p> <p>2</p> <p>2</p>	<p>Provided ✓</p> <p>P ✓</p> <p>P ✓</p>	<p>MR</p> <p>MR</p> <p>MR</p>
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A

dh

N/10

	• Hose Box	NA	NA	NA
13.	Pumping Arrangements.			
	Ground Level			
✓	➤ Discharge of main pump	2280 LPM	Provided /	MR
	➤ Head of Main pump	60 mtrs.	Provided /	MR
	➤ Number of main pumps	One	Two /	NMR
✓	➤ Jockey Pump out put	180 LPM	Provided /	MR
	➤ Jockey pump head	70 mtrs.	Provided /	MR
✓	➤ Standby pump out put	2280 LPM	NP /	NMR
	➤ Standby pump Head	60 mtrs.	— /	—
	➤ Auto Starting/Manual stopping	Required	Provided /	MR
	➤ Pump Hose Access			
	Terrace level	Jockey Pump 900 LPM	/	
✓	➤ Discharge of pump	dm	Provided /	MR
	➤ Head of the pump	50 mtrs.	Provided /	MR
	➤ Power supply	Required	Provided /	MR
	➤ Auto Starting of pump	Required	Provided /	MR
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	50,000 ltrs.	Provided /	MR
	➤ Draw -off connection	Required	Provided /	MR
	➤ Fire service inlet	Required	Provided /))
	➤ Access to tank	Required)) /	((

dm

N¹ 117

	➤ Overhead Tank Capacity	10,000 lbs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts	Lift is not going to basement		
	• Pressurization of Lift Shaft	Not Required	NP	NR
	• Pressurization of Lift lobby	Not Required	NP	NR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	- //	//	//
	• Lift Signage	Required	Provided	//
17.	Standby power supply	R.	① 125 KVA ② 62.5 KVA	MR
18.	Refuge Area			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	MR
	➤ Flow Switch Panel	//	//	-
	➤ PA system Panel	Required	Provided	MR
	➤ Batter backup	//	//	-
	➤ Building Floor plans	-	-	-
20.	Special Fire Protection Systems for	-	-	-
	Protection of special Risks, if any:	-	-	-

du

N/18

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Note! - 1. Draw off connection has been provided.
2. Pressurisation of lift lobby, lift & fireman switch has been provided.

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

~~MA 16/6~~
Sunil Chaudhary

Name

Designation

D.O (W)

Designation