

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2013/W2/547

Dated: 11/07/13

FIRE SAFETY CERTIFICATE

Certified that The M/s **Bik Foods** located at 101-103, 107-108 on first floor, CSC Market, BG-6, Paschim Vihar, New Delhi-63 comprised of ground + one upper floor owned and occupied by M/s **Bik Foods**, was earlier issued Fire Safety Certificate for running the trade of Bakery Products, sweets and Namkeen manufacturing by this department vide letter No. F6/DFS/MS/EH/09/3508 dated 20.11.2009. The premises was reinspected by the officer concerned of this department on 23.06.2013 in the presence of Sh. Ashu Taneja (Owner) & found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with NBC (Part-IV) and the building/premises is fit for occupancy Industrial (Group G) with effect from ..11./07./13..... for a period of 3 (three) years subject to conditions printed below.

Issued on11./07./13..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Ashu Taneja (Owner), M/s Bik Foods, 101-103, 107-108 on first floor, CSC Market, BG-6, Paschim Vihar, New Delhi-63.
2. Dy. Health Officer, North Delhi Municipal Corporation, Rohini Zone, Sector-5, Delhi-85.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

11/10
Building comprised G+IF
Trade Running at 1st Floor only

- 6/6
1. Name & address of the building : Bek Road, 101, 103, 107, 108
 2. Type of Occupancy : CSC Mkt. BG-6, Paschim Vihar, N-63
 3. Type of Case : Industrial Group (G)
old case (Renewal case)
 4. Details of previous NOC : F-6/DFS/MS/EH/09/3508 Dated 20/11/09
 5. Fire Safety directives letter No. : NBC (Part IV)
 6. Date of inspection : 23/6/13
 7. Name of the Inspecting Officers :
 8. Name and designation of officers : Ashu Tanuja (owner)
- From the building side
9. Year of Construction : old case (Renewal)
DHO/RZ/2013/90 Dated 23.4.13
 10. Applicant's letter No. :

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement ^{NBC 2005}	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6	Provided	MR ✓
	• Gate width	Accessible	Provided	MR ✓
	• Width of internal road	N/A	N/A	N/A ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	MR ✓
	• Basement	NA	NA	NA ✓
	b. Width of staircases	_____	_____	_____
		_____	_____	_____

MU

<ul style="list-style-type: none"> • Upper Floors • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door size	2	1.40m ²	MIR ✓
	N/A	N/A	N/A ✓
		NR	✓
			✓
	One	Provided	MIR ✓
	old case	old case	MIR ✓
old case	old case	MIR ✓	
3. Compartmentation.			
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
		NR	✓
4. Smoke Management System.			
<ul style="list-style-type: none"> • Basements • Upper floor 	N/A	N/A	N/A ✓
		open to sky	MIR ✓
5. Fire Extinguishers			
<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10	Provided	MIR ✓
	ABC 5kg	Provided	MIR ✓
	CO2 4.5kg Foam 9kg	Provided	MIR ✓
	ISI marks		
6. First-Aid Hose Reels.			

M/13

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>one</p> <p>30 m</p> <p>5 mm</p>	<p>Provided</p> <p>Provided</p> <p>Provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>	<p>✓</p> <p>✓</p> <p>✓</p>
7.	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 				
8.	MOEFA	Required	Provided	MR	✓
9.	Public Address System.	NR	NR	NR	✓
10.	Automatic Sprinkler system				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>100 mm</p> <p>one</p> <p>11</p>	<p>Provided</p> <p>11</p> <p>11</p>	<p>MR</p> <p>11</p> <p>11</p>	<p>✓</p> <p>✓</p> <p>✓</p>
12.	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants 	✓	✓	✓	✓

N/14

	• Hose Box			
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head		NR	
	➤ Standby pump out put			
	➤ Standby pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump Hose Access			
	Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR ✓
	➤ Head of the pump	40 MH	Provided	MR ✓
	➤ Power supply	Required	Provided	MR ✓
	➤ Auto Starting of pump	Required	Provided	MR ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection			
	➤ Fire service inlet			
	➤ Access to tank			
			NR	✓

M15

	➤ Overhead Tank Capacity	2500 lts	Provided	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NR	NR
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17.	Standby power supply	Required	Provided	MR ✓
18.	Refuge Area			
	➤ Total Area	NR	NR	NR
	➤ Location			
19.	Fire Control Room			
	➤ Detector System Panel	NR	NR	NR
	➤ Flow Switch Panel			
	➤ PA system Panel			
	➤ Batter backup			
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:	<p>① Small domestic oil based transformer (Step-up)</p>	<p>② No. Mechanical Foam Extinguishers</p> <p>③ lit Cap. provided</p>	MR ✓

N/6

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial number.....~~

~~Ak Jaiswal~~
23/6/13

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

A. K. JAISWAL

Name

Designation

ADDG/(JWP)

Designation