

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F.6/DFS/MS/2013/EH/W2/573

Dated: 18/07/13

FIRE SAFETY CERTIFICATE

Certified that the Gola Sizzlers (A unit of Kesari Hospitality Pvt. Ltd.) located at J - 2/14, B K Datta Market, Rajouri Garden, New Delhi - 110027 comprised of Basement, Ground plus Two Upper Floors with restaurants on Ground Plus Two Upper Floors was issued FSC vide letter no. F.6/DFS/MS/EH/2010/1864 dated 24-06-2010 was reinspected by the officers concerned of this department on 04.07.2013 in the presence of Mr. Mohit Nanda (Director) and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D of Sub Division-D 5 with effect from 18/07/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on18/07/13..... at New Delhi by.


18/7
(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service.
cfowz.dlfire@nic.in
Ph: 011-23414250

Copy to:

1. M/s Gola Sizzlers (A unit of Kesari Hospitality Pvt. Ltd.),
J - 2/14, B K Datta Market,
Rajouri Garden, New Delhi - 110027.
2. The Dy. Health Officer, Health Department,
West Zone, Rajouri Garden, New Delhi.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

r/6

Building comprised of B+G+Two upper floors

INSPECTION REPORT

1. Name & address of the building: Gale Sim-lars, J-2/14, Rajouri Garden, B.K. Datta Market, New Delhi-110027
2. Type of Occupancy : Assembly (Restaurant) G+2 upper floors
3. Type of Case : Renewal (170 sq. yards approx.)
4. Details of previous NOC : Letter No. F.6/PPS/MS/EN/2010/1064 dated 24-6-10
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 04-07-13
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer from the building side : Mr. Mohit Nanda
: Director
9. Year of Construction : 2007
10. Applicant's letter No. : Nil dated 25-06-13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NR	NR	NR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	Old case	Old case	Old case
	b. Width of staircases			
	• Upper floors	Old case	Old case	Old case
	• Basements	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	Old case	Old case	Old case
	f. Door Size	Old case	Old case	Old case

N/A

M

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A		
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour Required ✓	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour Required ✓	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 nos. ISI marked	10 nos. ABC & CO ₂ Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1 on each floor	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A		
8.	MOEFA	Required ✓	Provided	MR
9.	Public Address System	N/A		
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required ✓	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required ✓	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required ✓	Provided	MR

11	Internal Hydrants						
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	N/A					
12.	Yard Hydrants						
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 				N/A		
13.	Pumping Arrangements						
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A					
	450 lpm				Provided	MR	
	180 lpm				Provided	MR	
	40 m each				Provided	MR	
	Required				Provided	MR	
	Required	Provided	MR				
14.	Captive water Storage for fire fighting						
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank 	N/A					
	• Overhead Tank capacity				5000 lt.	Provided	MR
15	Exit Signage	Required	Provided	MR			
16.	Provision of Lifts	Required	Provided	MR			

N/A

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply	Required	Provides 125KVA Gen.	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Mukesh Verma

Name

Designation

ADOLMAN

Designation