

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.

F.6/DFS/MS/2013/School/W2/572


Dated:

18/07/13

**FIRE SAFETY CERTIFICATE**

Certified that the **H.B.M.Public School**, located at F-80, Laxmi Park, Nangloi Delhi-110041 comprised of ground floor only with plot area 700yard<sup>2</sup> and covered area 350yard<sup>2</sup> having total class rooms 7, owned and occupied by **Ch. Harphool Bharpai Devi Educational Society**, was earlier issued FSC by this department vide letter No. F.6/DFS/MS/09/13 dated 05.01.2009. The premises was re-inspected by the officer concerned of this department on 05.07.2013 in the presence of Sh. Lalit Kumar (Owner) of the school and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy Educational (Group B) with effect from .....18/07/13.....for a period of 3 (three) years subject to conditions printed below.

Issued on .....18/07/13..... at New Delhi by.

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Headmaster, H.B.M. Public School, F-80, Laxmi Park, Nangloi, Delhi-110041.
2. The Director of Education, Gov. of NCT of Delhi, Old Secretariat, Delhi.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc.may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2/2

Renewal,  
Ground floor only

**INSPECTION REPORT**

- 1. Name & address of the building: HBM Public School  
F-80, Luxmi Park, Nangloi, DL-41
- 2. Type of Occupancy : Edu
- 3. Type of Case : Renewal
- 4. Details of previous NOC : Letter No F-6/DFS/MS/09/13/dt 5.1.2009
- 5. Fire Safety directives Letter No. : DOE circular dt 17/01/2005
- 6. Date of inspection : 5/7/13
- 7. Name of the Inspecting Officer : ADO Akjaiswal
- 8. Name and designation of Officer  
from the building side : Lalit Kumar (owner)
- 9. Year of Construction : -
- 10. Applicant's letter No. : Nul

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL DOE 17.1.05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>P</u>	<u>MR</u>
	• Gate width	<u>—  —</u>	<u>P</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors			
	• Basements			
	b. Width of staircases			
	• Upper floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	<u>1.50 Mtr.</u>	<u>P</u>	<u>MR</u>
	f. Door Size	<u>1.00 Mtr.</u>	<u>P</u>	<u>MR</u>

NR (diagonal line across the table)

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour		NR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<sup>2</sup> ABC=1, CO <sub>2</sub> =1 ISI marked	P P P	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>			NR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			NR
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			NR

4/11

11.	Internal Hydrants			
	<ul style="list-style-type: none"><li>• Size of riser/down- comer</li><li>• Number of hydrants per floor</li><li>• Hose Box</li></ul>			NR
12.	Yard Hydrants			
	<ul style="list-style-type: none"><li>• Total number of hydrants</li><li>• Hose Box</li></ul>			NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"><li>• Ground Level</li><li>• Discharge of main pump</li><li>➤ Head of main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby Pump out put</li><li>➤ Standby Pump Head</li><li>➤ Auto Staring/Manual stopping</li><li>➤ Pump House Access</li><li>• Terrace level</li><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power supply</li><li>➤ Auto starting of pump</li></ul>			NR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"><li>• Under ground tank capacity</li><li>➤ Draw of connection</li><li>➤ Fire service inlet</li><li>➤ Access to tank</li><li>• Overhead Tank capacity</li></ul>			NR
15	Exit Signage			
16.	Provision of Lifts			NR

57N.

	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>			
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>			
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~



Signature of the Inspecting Officer: *A.K. Jaiswal*  
 Name: (A.K. Jaiswal)

Designation: ADO (JWP)

Signature of the Inspecting Officer: \_\_\_\_\_  
 Name: \_\_\_\_\_

Designation: \_\_\_\_\_