

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

Fax : 011-23412593 E-mail : cfohq.dlfire@nic.in Ph. 011-23414333.


No.F6/DFS/MS/2013/ *Audi / 556*

Dated :-----*12/07/13*

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium** located at **India Habitat Centre, Lodhi Road, New Delhi-110003**. comprised of **Basement, Ground + Mazenine (Balcony)** Audi is at GF&MZ Floor was granted NOC by this department vide letter No./F6/DFS/MS/2010/2507 dated 27/08/10 The premises was re-inspected by the officer concerned of this department on 03/07/13 in the presence of **Mr. Amar Nath** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for **Occupancy Class-D Assembly Building** with effect from ~~12/7/13~~ *12/7/13* ----- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued ~~-----~~ *12/7/13* -----at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Addl. Commissioner of Police, (Lic.),
First Floor, PS Defence, New Delhi

(2) Auditorium Located at India Habitat Centre,
Lodhi Road, New Delhi-110003.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/22-

INSPECTION REPORT

1. Name & address of the building:- Auditorium located at India Habitat Centre, Lodhi Road, New Delhi-110003.
2. Type of occupancy:- Group-D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No./F6/DFS/MS/2010/2507 dated 27/08/2010
5. Fire safety directives No.- N/A
6. Date of inspection:- 03/07/13.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Amar Nath.
9. Year of construction:- 1993.
10. Applicant's letter No:-17244-48/Addl.C.P./Lic.(Amst.) dated 12/04/2013 Basement, Ground + Mazenine (Balcony) Audi is at GF&MZ Old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12Mtrs.Required	Provided.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr.	170cmsx3,166cmsx2,75cms x 4.	MR Old case
3.	Compartmentation			
	1) Fire check door	Required	Provided in Basement	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan provided	MR
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR

A. Kaushik

5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	15 Nos.	MR
	2) Types		ABC & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Yes	Two on both side of stage	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke	MR
	2) Location of main panel	Required	GF Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	100 mm.	MR
	2) Number of hydrants per floor	Required	2 Nos. in each block	MR
	3) Hose box	Required	2 Nos. in box	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement	Provided & maintained by Habitat Centre Management		
	1) Ground level			
	a) Discharge of main pump	----do-----	----do-----	----do-----
	b) Head of main pump	----do-----	----do-----	----do-----
	c) Number of main pump	----do-----	----do-----	----do-----
	d) Jockey pump out put	----do-----	----do-----	----do-----
	e) Jockey pump head	----do-----	----do-----	----do-----
	f) Stand by pump output	----do-----	----do-----	----do-----
	g) Stand by pump head	----do-----	----do-----	----do-----
	h) Auto starting/Manual stopping	----do-----	----do-----	----do-----
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting :- Provided & Maintained by Habitat Centre			
	1) Under ground tank capacity	----do-----	----do-----	----do-----
	a) Draw-off connection	----do-----	----do-----	----do-----

Daisy

1479

	b) Fire service inlet	----do-----	----do-----	----do-----
	c) Access to tank	----do-----	----do-----	----do-----
	d) Over head tank capacity	----do-----	----do-----	----do-----
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	Yes	Provided	MR
	c) PA system panel	Yes	Provided	MR
	d) Battery backup	Yes	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010-----

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj

Name:- S.S. Kaushik.

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer

