

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/school/2013/W2/548

Dated: 11 / 07 / 2013

**FIRE SAFETY CERTIFICATE**

Certified that the **Navjeevan Convent School** comprised of **Ground floor only with 10 No's of Class Rooms** located at **Shradhanand Colony, Delhi-110042** owned / occupied by **Navjeevan Convent School** has already been issued fire safety certificate **Vide letter no F-6/DFS/MS/09/3520 Dated 23/11/2009.** The premises was re-inspected by the officer concerned of this department on dated **10/06/2013** in the presence of **Ms Shahnaz Khan** and observed that **8 No's sheds** have now been added in the school premise. The premise deem of complied with fire prevention & fire safety requirement in accordance with the **circular no.262-363 at 17/01/2005** issued by **Director of Education.** The premise is fit for occupancy of **Group Class B (Educational)** with effect from **11 / 07 / 2013** for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 11/07/13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:-**

1. The Principal, Navjeevan Convent School, Shradhanand Colony, Delhi-110042.
2. The Director of Education, Old Secretariat, Delhi.

Renewal

INSPECTION REPORT

1. Name & address of the building: Navjeevan Convent School, Shradhanand Colony, Educational. - Bhalswa Dairy, Delhi-42.
2. Type of Occupancy: Educational.
3. Type of Case: : New Case/ Renewal
4. Details of previous NOC: : Letter No F-6/DPS/mrs/09/3520 Dated: 23-11-2009
5. Fire Safety directives letter No: Circular, Dir. of Edun., 262-362 dt. 17-1-2005.
6. Date of inspection: : 10-6-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Ms. Shahnaz Khan (H.M.)
9. Year of Construction: 1994, (Ground only) ① 3 No's Pucca Rooms & ② 8 No's Sheds.
10. Applicant's letter No.: Nil dated 23-5-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	Accessible 6 m	NIR
	• Gate width	- - - 2.5 m	- - -
	• Width of internal road	NIA	NIA
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	NIA	
	• Upper Floors		
	• Basements		
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits		
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace		
	g. Width of Corridor		
	h. Door Size	1 m	1 m (one door, less than 100 student.) NIR
3	Compartmentation.		
	• Fire check door	NIR	
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	NIR
	• Upper floors	12 a/c per hour	

5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>03 ABC/CO2 (2.5kg) ISI marked</p>	<p>05 ABC Provided</p>	<p>MIR MIR MIR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m 5 mm</p>	<p>NIR /</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		<p>NIR  </p>	
8	MOEFA			<p>NIR</p>
9	Public Address System.			<p>NIR</p>
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		<p>NIR  </p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		<p>NIR  </p>	
12	Yard Hydrants..			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		<p>NIR  </p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		<p>NIR  </p>	

n/h

14	Captive Water Storage for fire fighting.		NIR	
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>			
15	Exit Signage.		NIR	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>			
17	Standby power supply		NIR	
18	Refuge Area.		NIR	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	Fire Control Room		NIR	
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	Nil	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DO (NW)

12/6/13

Signature of the Inspecting Officer

Name

Designation

SHYAM LAL  
11/6/2013

(SHYAM LAL)

Assist. Divn. Officer