

No. f6/OFS/MS/School/2013/12/553

Dated: 12.07.2013

FIRE SAFETY CERTIFICATE

Certified that the Nigam Prathmik Vidyalaya (Boy),2/II located at Camp No.1, J.J. colony Nangloi, Delhi-110041 is comprised of ground + one upper floor only with 30 rooms, owned and occupied by Nigam Prathmik Vidyalaya (Boy),2/II. The premises was re-inspected by the officer concerned of this department on 01.07.2013 in the presence of Sh. Shrikishan (Principal) and observed that 26 rooms are being used as class rooms and remaining 4 rooms as administrative purpose. The Fire prevention and fire Safety arrangements provided in the premises, found in good working condition. The premises have complied with the fire prevention and fire safety requirements in accordance with Director of Education circular dated 01.03.2011. and that the building/premises is fit for occupancy Educational with effect from 12.07.2013 for a period of 3 (three) years subject to conditions printed below.

Issued on 12.07.2013 at New Delhi by.

(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. The Principal, Nigam Prathmik Vidyalaya (Boy),2/II located at Camp No. 1, J.J. Colony Nangloi, Delhi-110041.
2. The Director of Edu, Gov. of NCT of Delhi , Old Secretariat , Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc.may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt..nic.in.

Total Room = 30 Plot Area = 6992.4 m²
 class Room = 26 Covered Area = 1250 m²
 Total student = 656 (656)

INSPECTION REPORT

1. Name & address of the building : Nigam Prathmic Vidyalaya (Boys)
2. Type of Occupancy : 2/II, Camp No. 1, JJ Colony, Nangla Daku
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: (G+one upper floor)
5. Fire Safety directives letter No : DOE circular dt 1/3/11
6. Date of inspection : 1/7/13
7. Name of the Inspecting Officers : A.K. Jaiswal
8. Name and designation of officers from the building side : Shri Shri Kishan
9. Year of Construction : _____
10. Applicant's letter No. : Nil dt 26/2/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	DOE circular dt 1/3/11		
	• Road width	6 Mtr.	Provided	MR
	• Gate width	5 Mtr.	Provided	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	MR
	b. Width of staircases			
	• Upper Floors	1.50 Mtr.	1.20 X 2	MR
	• Basements			
	c. Protection of exits			
	• Fire check door			MR
	• Pressurization			
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	1.50 Mtr.	Provided	MR
	h. Door Size	1.00 Mtr.	Provided	MR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR		
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NR		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NR		
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

AK Jaiswal
11/7/13

Signature of the Inspecting Officer

Name

A.K. JAISWAL

Designation

ADD (JWP)

Signature of the Inspecting Officer

Name

Designation