

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2013 / N 02 / 561

Dated 16 / 07 / 13

FIRE SAFETY CERTIFICATE

Certified that **The Host Restaurant** located at **F-8 / F-33, Connaught Place, New Delhi** at **ground floor & mezzanine floor** occupied by **The Host Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of the fire service on 11/07/2013 in the presence of Sh. Pankaj Gaur, Manager and the said building / premises is fit for occupancy **Class Group A Residential / Group D Assembly Building** with effect from 16/07/13 2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....16/07/13..... at New Delhi by.

  
(Dr G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph – 011-23414333

Copy to:-

1. The Host Restaurant / Host Inn Guest House, F-8 / F-33, Connaught Place, New Delhi.
2. The Licensing Authority, Health department, NDMC, Palika Kendra, New Delhi.
3. The Dy. Secy, Tourism Department, GNCT of Delhi, C-Wing, 2<sup>nd</sup> floor, Vikas Bhawan-II, Upper bela Road, delhi – 54.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

## INSPECTION REPORT

1. Name & address of the building: M/s THE HOST RESTAURANT  
F-8 CONNAUGHT PLACE New Delhi
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : Letter No FG/DFS/MS/GH/2019/3799 Dt 16/12/19
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 29/6/13
7. Name of the Inspecting Officer : ADO Manoj K. Sharma  
DCFO RASOBI PANWAR
8. Name and designation of Officer  
 from the building side : Sh. Pankey Gaur Mehar Rest.
9. Year of Construction : 1987 Starty Year
10. Applicant's letter No. : Nil. Dt. 14/6/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mts	More than 6 Mts.	MR.
	• Gate width	-	Directly Access	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR.
	• Basements	-	-	-
	b. Width of staircases			
	• Upper floors - 2. (Mez.)	1.25 1.75	1.30 Mts 1.75 Mts	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

1.	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N.A.	N.A.	N.A.
	f. Door Size	N.A.	N.A.	N.A.
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	N.A.	N.A.
	• Upper floors	12 a/c per hour	N.A.	N.A.
5.	Fire Extinguishers			
	• Total numbers	05	Provided	MR
	• Types	Water CO <sub>2</sub> CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked ABC	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Not Required	Provided Heat & Smoke	MR
	• Location of Main Panel	N-R.	Provided at Reception	MR
	• Location of Repeater Panel	N-A	N-A.	N-A.
	• Alternate source of power	N R	P	MR
	• Hooters' Location	Not Required	Each Floor	MR
8.	MOEFA	Required	Provided	MR.
9.	Public Address System	N.A.	N.A.	N.A.
10.	Automatic Sprinkler System	Required	Provided	MR

Meth

	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA Required NA.	NA Provided N.A.	NA MR NA.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA. NA NA	NA NA NA	NA. NA NA.
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	 NA. N.A. N.A. NA N.A. N.A. N.A. N.A. N.A. R - 900 LPM 40 M Required 	 N.A. N.A. N.A. NA NA N.A. N.A. N.A. NA P - Provided Provided Provided at G'Flw 	 N.A. NA NA NA NA NA NA NA NA MR - MR. MR MR MR MR 
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> </ul>	NA NA N.A.	NA NA N.A.	NA NA NA.

	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	10,000 (5000+5000) Required	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	N.A.	N.A.	NO
	➤ Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply	Required	62 KVA	MR
18.	Refuge Area			
	➤ Total area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19.	Fire control room			
	➤ Detector system panel	N.A.	N.A.	N.A.
	➤ Flow Switch Panel			
	➤ PA System Panel			
	Batter backup			
	Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 Fire Batts Provided	MR



The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name RAJESH PANDEY

Signature of the Inspecting Officer

Name M.K. SHARMA