

No. FB DFS/MS/2013/122/school/571

Dated: 18/07/13

FIRE SAFETY CERTIFICATE

Certified that **The Panch Jyoti Public School** located at D-5/146, Kunwar Singh Nagar, Nangloi, New Delhi- 41 comprised of ground floor only with 7 class rooms & a library owned and occupied by **Panch Jyoti Public School**, have complied with the fire prevention and fire safety requirements in accordance with circular issued by Director of Education, Govt. of NCT vide letter no. F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 06.07.2013 in the presence of Sh. Ram Singh (Manager) and the building / premises is fit for occupancy Educational (Group B) with effect from 18/07/13.....for a period of 3 (three) years subject to conditions printed below.

Issued on 18/07/13..... at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. The Manager, Panch Jyoti Public School, D-5/146, Kunwar Singh Nagar, Nangloi, New Delhi- 41.
2. The Director of Education, Gov. of NCT of Delhi, Old Secretariat, Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

G Family

PA = 700 yard²
CA = 400 yard²

N/1

INSPECTION REPORT

1. Name & address of the building: Danesh jyoti Public School
D-5/146, Krunwar Singh Nagar
Nangloi, Delhi-41
2. Type of Occupancy : Edu
3. Type of Case : New *G Family with 7 classrooms & a library*
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : DOE circular 1/3/11
6/7/13
6. Date of inspection : —
7. Name of the Inspecting Officer : ADO AK jaiswal
8. Name and designation of Officer
from the building side : Ram Singh Manager
9. Year of Construction : 2008
10. Applicant's letter No. : Nil dt Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL DOE Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	<u>DOE 1.3.11</u>		
	• Road width	<u>Accessible</u>	<u>P</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>P</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors			
	• Basements			
	b. Width of staircases			
	• Upper floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	<u>1.50 M</u>	<u>P</u>	<u>MR</u>
	f. Door Size	<u>1.00 M</u>	<u>P</u>	<u>MR</u>

N/V

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NR	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour		
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	NR	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 ABC/CO2	P	MR
		ISI marked	P	MR
			P	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		NR	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NR	
8.	MOEFA		NR	
9.	Public Address System		NR	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		NR	

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 		NR	
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		NR	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 		NR	
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NR	
15	Exit Signage		NR	
16.	Provision of Lifts			

N/V

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply		NR	
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		NR	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		NR	
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer
AK Jaiswal
 6/7/13

Signature of the Inspecting Officer

Name (ASHOK KUMAR JAISWAL) Name

Designation ADO/(JWP)

Designation