

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfhq.dlfire@nic.in

No. FG/DPS/MS/2013/440

Dated 13/6/2013

FIRE SAFETY CERTIFICATE

Certified that the Bharti Public School, Swasthya Vihar, Vikas Marg, Delhi, comprises of ground & three upper floors was granted NOC by this deptt. vide letter No. F6 / DFS / MS / 99 / 2876 dated 11 - 03 - 1999. The premises was re-inspected by the officer concerned of this department on 22-05-2013 in the presence of Mr. Rajesh and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class B 'Educational Building with effect from 13-6-2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 13/6/2013 at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph. 2341333

gc
RSD
12/6/13

Copy to:-

1. The Principal
Bharti Public School Swasthya Vihar,
Vikas Marg, Delhi
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

-N/8-

INSPECTION REPORT

1. Name & address of the building: Bharti Public School Sawasthya
Vihar, Vikas Marg, Delhi
2. Building is comprised of : Ground & three upper floors
3. Type of Occupancy. : Educational.
4. Type of Case : Renewal.
5. Details of Previous NOC letter: F6/DFS/MS/99/2876 dated 11.3.1999
6. Fire Safety direction letter No :
7. Date of Inspection : 25-05-2013
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Mr. Rajesh Batra
from the building side
10. Year of Construction : 1996
11. Applicant's letter No : BPS/13/6446 dated 03-04-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	NBC /Existing Requirement.	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5Mtr NA	30 ft 4.5 Mtrs	MR MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	2Nos.	4Nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 Mtr NA	1.5,1.46,1.47 &1.5 Mtr NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA -----	NA -----	NA -----
	e. No. of continuous staircases to terrace	02Nos.	04Nos.	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1.0Mtr	1.0mtr	MR

-N/A-

M

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5	Fire Extinguishers			
	• Total numbers	17 Nos.	17 Nos.	MR
	• types	ABC&CO2	ABC& CO2	MR
	• IS marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	3No each floor	3No each floor	MR
	• Length of hose reel hose	30Mtr.	30Mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	Required	Provided	MR
	Hooter's location	-----	-----	-----
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10.	Automatic Sprinkler System.	NA	NA	NA
	• Basement
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants	NA	Provided	
	• size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	2no	2no	MR
	• Hose Box	2No	2No	MR
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants
	• Hose Box
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----

-11/10- Bhareli Public School,
Swarthya vihar, vikas marg,
Delhi

	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	40Mtr	40 Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50000 Ltr.	50000Ltr.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000Ltr.	5,000Ltr.	MR
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	NA	NA	NA
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----

-17/11-

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name *W. Singh*
31/5/13
(GURMUKH SINGH)
Designation ADD(LN)