

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F.6/DFS/MS/School/2013/ 583

Dated: 19/07/13

**FIRE SAFETY CERTIFICATE**

Certified that the building of Smt. Lilawanti Saraswati Shishu Mandir, FB Block, Tagore Garden, New Delhi - 110027 comprised of ground plus one upper floor, having total 14 rooms owned and occupied by Smt. Lilawanti Saraswati Shishu Mandir was inspected by the officer concerned of this department on 28.06.2013 in the presence of Mrs. Bhatti and found complied with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for the occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on ..... 19/07/13 ..... at New Delhi.

  
13/7  
(SANTOKH SINGH)  
Chief Fire Officer,  
Delhi Fire Service.  
cfowz.dlfire@nic..in  
Ph: 011-23414250

Copy to:-

1. Smt. Lilawanti Saraswati Shishu Mandir,  
FB Block, Tagore Garden, New Delhi - 110027
2. Director of Education,  
North Delhi Municipal Corporation,  
Dr. S.P.M Civic Centre,  
Minto Road, New Delhi-110002

5/16  


Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/3

**INSPECTION REPORT**

1. Name & address of the building: Smt. Lilavanti Saraswati Shishu Mandir  
Tigare Garden, FB-Block.
2. Type of Occupancy : Educational (G+1) 14 Rooms only
3. Type of Case : New
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : F.16/Estate/CC/Fire Safety/2011/3298-3398 dt. 1/3/11
6. Date of inspection : 28-6-13
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer Ms. Bhatti  
from the building side : —
9. Year of Construction : 1991
10. Applicant's letter No. : Nil dt. 30-4/13

Total Area = 1069 sq. yards Covered Area = 416 Sq. Yards

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL D.O.E code Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u> ✓
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u> ✓
	• Width of internal road	<u>N.R.</u>	<u>N.R.</u>	<u>N.R.</u> ✓
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>2</u>	<u>Provided</u>	<u>MR</u> ✓
	• Basements	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u> ✓
	b. Width of staircases			
	• Upper floors <u>Clause 3 C (b)</u>		<u>1. 128cm/90cms varying</u>	<u>MR</u> ✓
	• Basements	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u> ✓
	c. Protection of exits			
	• Fire check door	<u>N.R.</u>	<u>N.R.</u>	<u>N.R.</u> ✓
	• Pressurization	<u>N.R.</u>	<u>N.R.</u>	<u>N.R.</u> ✓
	d. No of continuous staircase to terrace	<u>No Terrace</u>	<u>No Terrace</u>	<u>MR</u> ✓
	e. Width Of Corridor	<u>1.5m</u>	<u>1.5m</u>	<u>MR</u> ✓
	f. Door Size	<u>1m</u>	<u>1m</u>	<u>MR</u> ✓

N/A

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	3 @ 300 sym. ISI marked	6 ✓ ABC + CO2 Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>		N/A	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		N/A	
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>		N/A	

	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>		N/A	
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		N/A	
15	Exit Signage		N/A	
16.	Provision of Lifts			

N/6

	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>			
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>			
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>			
20.	Special Fire Protection Systems for Protection of special Risks, if any;			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

*..... D.O.E. cellular ..... 1:3:11 it is recommended to grant fire safety certificate*

Signature of the Inspecting Officer *Mukesh Verma*

Name *Mukesh Verma*

Designation *ADD (M)*

Signature of the Inspecting Officer

Name

Designation

