

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2013/591

Dated: 22/07/13

FIRE SAFETY CERTIFICATE

Certified that **Om International School** located at Kotla Vihar, Phase 2 (Near Village Shiva Mandir), New Delhi-110041 comprised of ground floor only having 9 class rooms, owned and occupied by **Om International School**, have complied with the fire prevention and fire safety requirements in accordance with circular issued by Dire. of Education, Govt. of NCT vide letter No. 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 11.07.2013 in the presence of Sh. Om Jeet Singh (Owner) and the building/premises is fit for occupancy Educational with effect from ..22./07./13..... for a period of 3 (three) years subject to conditions printed below.

Issued on22./07./13..... at New Delhi by.



(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. The Manager, Om International School, Kotla Vihar, Phase 2 (Near Village Shiva Mandir), New Delhi-110041.
2. The Director of Edu, Gov. of NCT of Delhi , Old Secretariat , Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour		
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour		NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02+01 ABC/CO2 ISI marked	02 ✓ Provided ✓ Provided ✓	MIR NR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 			NR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			NR

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 			NR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 			NR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NR
15	Exit Signage			
16.	Provision of Lifts			

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 			
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 ~~issue shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer *Ak Jaiswal* 11/7/13

Name (A-K. JAISWAL)

Designation ADO/(JWP)

Signature of the Inspecting Officer

Name

Designation

