

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/FH/2013/W2/602 Dated: 23/07/2013

FIRE SAFETY CERTIFICATE

Certified that the Shiv Farm, located at, Palla Bakhtawar Pur Road comprised of Ground floor + one upper floor is built on a plot area of 3.0 acre land with covered area of approximately 200 square yard is owned / occupied by Sh Sanjeev, have complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 28/05/2013 in the presence of Sh Sanjeev, and that the building / premises is fit for occupancy Class Sub Div. D-5 Assembly Buildings with effect 23/07/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. The fire safety certificate recommended for 300 persons only.

Issued on 23/07/2013 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Executive Engineer (Building), Municipal Corporation of Delhi, Narela Zone, Zonal Office Building, Narela, Delhi with reference to the **letter No AC/NRZ/2013/490 dated 05/02/2013**
2. Sh Sanjeev, Shiv Farm, Palla Bakhtawar Pur Road, Delhi

May kindly see the **letter No AC/NRZ/2013/490 dated 05/02 /2013** received from Assistant Commissioner (MCD), Narela Zone regarding issuance of NOC from fire safety and fire prevention point of view in respect of **Shiv Farm** located at **Palla Bakhtawar Pur Road,** Delhi for holding social function such as wedding and parties etc.

Accordingly the farm house premise was visited and inspected by the undersigned along with **Sh Sanjeev** on **dated 28/05/2013** as per **Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010** and it was observed that the farm house is comprised of **Ground floor + one upper floor** having a **total plot area of approx 3.0 acre.** The permanent structure covers approximately **200 sq yards.** With **GF having 02 Rooms & Dinning hall & FF 2 rooms.**

Remaining portion is open green, temporary shed, parking and road etc. No permanent sitting arrangement was seen at the time of inspection. The premise is approachable from Palla Bakhtawarpur main road of **60 feet.** There was no electric over head wiring.

**As regards to the fire protection arrangements, the status is as under.**

S/NO.	Fire Safety Provision	Provided / Not Provided
1.	Access to building	Accessible & NOC already issued by team.
2.	Number, width type and arrangement of exits	1 Mtr
3.	Protection of exits by means of fire checks door (s) and or pressurization.	N/A
4.	Compartmentation	N/A
5.	Smoke Managements system	Exhaust fan Provided
6.	Fire Extinguishers	08 ABC type & functional
7.	Fire Aid Hose Reels	Provided
8.	Automatic Fire detection and alarming system	N/A
9.	MOEFA	Provided & functional
10.	Public Address System	N/A
11.	Automatic sprinkler system	N/A
12.	Internal Hydrants and Yard Hydrants	Provided & functional
13.	Pumping Arrangements 450 LPM	450 LPM, provided & functional
14.	Captive water Storage for fire 10000 ltr	10000 ltr provided & full
15.	Exits Signage	Provided
16.	Provision of lifts	N/A
17.	Standby power supply	62.5 KVA
18.	Refuge Area	N/A
19.	Fire Control Room	N/A
20.	Special fire protection systems for protection of special risks	---