

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110 001


No. F6/DFS/ms/School/2013/W2/610

Dated: 24/07/13

FIRE SAFETY CERTIFICATE

Certified that **The School of Hope** (Name of the Building or premises) located at RZF-72, on 1st & 2nd floor, Nihal Vihar, Nangloi, Delhi-110041 comprised of ground + two upper floors only with 8 class rooms, owned and occupied by **The School of Hope**, have complied with the fire prevention and fire safety requirements in accordance with circular issued by Dte. of Education, Govt. of NCT vide letter no. F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 21.06.2013 in the presence of Sh. T.T. Pandian (Owner) and the building/premises is fit for occupancy Educational with effect from 24/07/13...for a period of 3 (three) years subject to conditions printed below.

Issued on 24/07/13..... at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Owner, The School of Hope, RZF-72, Nihal Vihar, Nangloi, Delhi-110041.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

2-1

Plot Area 500 yard² School at 1st & 2nd floor only
 Covered Area 269 yard² Total Rooms = 10
 class Rooms = 8 (1st + Floor = 4)
 2nd floor = 4

INSPECTION REPORT

1. Name & address of the building: The School of Hope, RZF-72
Nihalvihar, Nangloi, Delhi-41
2. Type of Occupancy : Edu
3. Type of Case : New
4. Details of previous NOC : Letter No Nil
5. Fire Safety directives Letter No. : DOE circular dated 01/03/2011
6. Date of inspection : 21/6/2013
7. Name of the Inspecting Officer : ADO A.K. Jaiswal
8. Name and designation of Officer
 from the building side : Shri T.T. Pandian (owner)
9. Year of Construction : 2005-06
10. Applicant's letter No. : TCH/RECOG/Fine/2013 dt 15/4/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	DOE Cir. 1.3.11		
	• Road width	Accessible	Provided	✓ MR
	• Gate width	Accessible	Provided	✓ MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.35 x 1 1.15 x 1	✓ MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR		
	• Pressurization	NR		
	d. No of continuous staircase to terrace	1	Provided	✓ MR
	e. Width Of Corridor	1.50 Mtr.	Provided	✓ MR
	f. Door Size	1.00 Mtr.	Provided	✓ MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	open to sky	NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2+1 ABC/CO ₂ ISI marked	Provided (10)	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one at each floor	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 M	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			NR

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 		NR	
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		NR	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access 		NR	
	• Terrace level	450 lpm	Provided	MR ✓
	➤ Discharge of pump	40 MH	Provided	MR ✓
	➤ Head of the pump	Required	Provided	MR ✓
	➤ Power supply	Required	Provided	MR ✓
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NR	
		10,000	20,000	MR ✓
15.	Exit Signage	Required	Provided	MR ✓
16.	Provision of Lifts			

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply		NA	
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		NR	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		NR	
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

N-5

AK Jaiswal
21/6/2013

Signature of the Inspecting Officer

Name

(AK, JAISWAL)

Designation

ADO (Twekpur)

Signature of the Inspecting Officer

Name

Designation