

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2013/W2/603 Dated: 23/07/2013

FIRE SAFETY CERTIFICATE

Certified that the M/s Veggitopia Family Restaurant located at 109, FF, SG Shopping Mall, Plot No -8, Commercial Centre, DC Chowk, Sector -9, Rohini, Delhi 110085 was granted Fire Safety Certificate by this department vide letter no F-6/ DFS MS/EH/2010/357 Dated 05/02/2010. The premises was re-inspected by the officers concerned of this department on 10 / 06 / 2013 in the presence of Sh. Pawan Aggarwal and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 23 / 07 / 2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 23/07/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Rohini Zone, Sector-V, Rohini, Delhi-110085 for information w r t letter No DHO/RZ/2013/163 dated 09/05/2013
2. The Sh Satish, M/s Veggitopia Family Restaurant with 148 seats located at 109, FF, SG Shopping Mall, Plot No -8, Commercial Centre, DC Chowk, Sector -9, Rohini, Delhi 110085

INSPECTION REPORT


1. Name & address of the building : M/S Veggitopia Family Restaurant (with 148 seats)
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2010/357 Dated 05/02/2010. ✓
5. Fire Safety directives letter No :
6. Date of inspection : 10 / 06 / 2013 ✓
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW) ✓
8. Name and designation of officers
from the building side : Sh. Pawan Aggarwal
9. Year of Construction :
10. Applicant's letter No. : DHO/RZ/2013/163 Dated 09/05/2013. ✓

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6m -- --	P -- --	M/R -- --
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1 1	1 ✓ 1 ✓	M/R ✓ M/R ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Old case Old case	Old case ✓ Old case ✓	Old case ✓ Old case ✓
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	R --	P ✓ --	M/R ✓ --
	e. No. of continuous staircases to terrace			
		--	--	--
	g. Width of Corridor			
	h. Door Size	Old case	p ✓	M/R ✓
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	R -- -- -- --	P ✓ -- -- -- --	M/R ✓ -- -- -- --
4	Smoke Management System.		Exhaust Fan Provided	
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	--	--

5. Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	O4	04	M/R
		ISI marked	ABC	M/R
			Yes	M/R
6 First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	one	Provided with mall	M/R
		30 m	P	M/R
		5 mm	P	M/R
7 Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	R	P	M/R
		Out side	P	M/R
		--	--	--
		R	P	M/R
		R	P	M/R
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.	Available with mall		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A	--	--
		R	P in Restaurant	M/R
		--	--	--
11 Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	R	P with mall	M/R
		1	1	M/R
		1	1	M/R
12 Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	--	--	--
		--	--	--
13 Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply 			
		2850 LPM	Provided with Mall	M/R
		60 m	Provided with Mall	M/R
		180 LPM	Provided with Mall	M/R
		60m	Provided with Mall	M/R
		2850 LPM	Provided with Mall	M/R
		60m	Provided with Mall	M/R
		R	P	M/R
		R	P	M/R
		--	--	--
		900LPM	P	M/R
		35m	P	M/R

M/9

	➤ Auto Starting of pump	R	P	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,50,000 ltrs	Provided with Mall	M/R
	➤ Draw-off connection	R	Provided with Mall	M/R
	➤ Fire service inlet	R	Provided with Mall	M/R
	➤ Access to tank	R	P	M/R
	• Overhead Tank capacity	30,000 ltr	Provided with Mall	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	--	--	--
	• Pressurization of Lift lobby	--	--	--
	• Communication In lift Car	--	--	--
	• Fireman's Grounding Switch	--	--	--
	• Lift Signage	R	P	M/R
17	Standby power supply	R	Provided with Mall	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	--	--	--
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name
Designation

[Handwritten Signature]
12/5/13