

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E Mail:- cfohq.dlfire@nic.in

Ph. No. 011-23414333


No.F.6/DFS/MS/School/2013/ 52/617

Dated: 25/07/13

FIRE SAFETY CERTIFICATE

Certified that the building of **Convent of Jack - N - Jill School** located at RZ-25, Indra Park, Uttam Nagar, New Delhi-110059 comprised of ground floor plus three upper floors but the school is running at ground floor only, having total 08 rooms (Including 06 Class Rooms, 01 Play Room & 01 Office) owned/occupied by the school management was inspected by the officer concerned of this department on 03.07.2013 in the presence of Dr. Mukesh Mehta (Proprietor) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 25/07/13.....at New Delhi.


(Dr. G C Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Proprietor,
Convent of Jack- N -Jill School, RZ-25,
Indra Park, Uttam Nagar, New Delhi-59.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

52
01/7

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/1

INSPECTION REPORT

1. Name & address of the building: **CONVENT OF JACK-N-JILL, RZ-25, Indra Park opp. A-1, Janakpuri, Banka Rd NO-59**
2. Type of Occupancy: **Educational**
3. Type of Case: **New Case/Renewal**
4. Details of Previous NOC: Letter No. **—** Dated **—**
5. Fire Safety directives letter No: **—**
6. Date of inspection: **03-07-2013**
7. Name of Inspecting Officer: **A.D.O Sandeep Duggal**
8. Name and designation of officers from the building side: **Ds Mukesh Mehta (Proprietor)**
9. Year of Construction: **1999-2000**
10. Applicant's letter No.: **Nil dated 18/06/2013**

| No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Circular dt. 01.03.2011 | Provided at site | Remarks MR/NMR |
|-----|---|--------------------------------------|------------------|--|
| 1. | Access to building | | | |
| | • Road width | Accessible | 5.5 m | MR |
| | • Gate width | — | — | — |
| | • Width of internal road | — | — | — |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | — | — | School Running at Ground Floor only |
| | • Upper Floors | — | — | — |
| | • Basements | — | — | — No Basement |
| | b. Width of staircases | | | |
| | • Upper Floor | — | — | School Running at Ground Floor only |
| | • Basements | — | — | — |
| | c. Protection of exits | | | |
| | • Fire check door | — | — | — |
| | • pressurization | — | — | — |
| | d. No. of continuous staircases to terrace | — | — | — |
| | e. Width of Corridor | — | — | — |
| | f. Door Size | 1m | 1m | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | — | — | — |
| | • Sealing of electrical shafts | — | — | — |
| | • Fire Rating of shaft door | — | — | — |
| | • Water Curtain | — | — | — |
| | • Fire Dampers | — | — | — |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | — | — |
| | • Upper floors | — | — | — |

N/2

| | | | | |
|-----|--|--------------------------------|------------------------------|----------------|
| | | 12 a/c per hour | | |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 03 (5kgs) ABC ISI marked | 03 (5kgs) ABC type Yes | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 30 m 5 mm | | |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | | | |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | | | |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | | | |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | | | |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping | | | |

N/3

Jack - N+ JILL, R2-25, Indra Park,
opp A-1, Janakpuri, Pankhe Road, ND-59

| | | | | |
|------------|---|---|---|---|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | — | — | — |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | — | — | — |
| 15. | Exit Signage. | — | — | — |
| 16. | Provision of Lifts: | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | — | — | — |
| 17. | Standby power supply | — | — | — |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | — | — | — |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | — | — | — |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | — | — | — |

N/4

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- The building is comprised of ground floor plus three upper floors, but the school is running at Ground floor only, The declared regarding this defect is enclosed vide not. nil dated 03/07/2013.

Sandeep
12/7/13

Signature of Inspecting Officer

Name **SANDEEP DUGGAL**

Designation **Asst. Div. Officer.**

Signature of Inspecting Officer

Name

Designation